



## Public Works Department

June 18, 2024

Ms. Sharon Fox  
Teton County Planning  
150 Courthouse Drive, Suite 107  
Driggs, Idaho 83422

---

RE: Engineering Review  
Moose Hollow Estates Subdivision Final Plat  
Section 15, T3N, R45E B.M.

---

Upon review of the Moose Hollow Estates Subdivision Final Plat, I have the following observations:

- Improvement Plan does not include communication utilities. Section 2 of the Moose Hollow Estates includes both electrical and telephone service. No linework for telephone is shown on the Electrical Plan but conduit is mentioned in trench detail. Applicant should confirm telephone will be provided to all lots.
- Lot 1 will need to access from the proposed interior subdivision road. A second access to W9500S will not be permitted.
- An Access Permit will be required from Road & Bridge to tie onto 9500S

Sincerely:

A handwritten signature in black ink, appearing to read "Darryl Johnson".

Darryl Johnson, P.E., P.L.S.  
Public Works Director