



# CONSULTANTS

y2consultants.com  
307 733 2999

ENGINEERING, SURVEYING & PLANNING  
LANDSCAPE ARCHITECTURE, GIS  
NATURAL RESOURCE SERVICES



## LEVEL I NUTRIENT PATHOGEN EVALUATION

### JC RANCHES SUBDIVISION

**Prepared by:**

Y2 Consultants, LLC  
Adrienne Lemmers

**Reviewed By by:**


Seied Zia A. Yasrobi, PE

**Prepared for:**

Idaho Department of Environmental Quality  
900 N. Skyline Drive, Suite B  
Idaho Falls, ID 83402

Eastern Idaho Public Health District  
820 Valley Centre Drive  
Driggs, ID 83422

Teton County Planning and Zoning  
89 North Main Suite 6  
Driggs, Idaho 83422



# CONTENTS

Introduction .....	1
Well Driller Reports.....	1
Section 2 Well Summary .....	5
Section 3 Well Summary .....	5
Section 10 Well Summary .....	5
Section 11 Well Summary .....	5
Overall Well Log and Topography Observations.....	5
Soil and Surface Geologic Conditions .....	6
Background Nitrate Concentration .....	7
Nitrogen Mass Balance Spreadsheet.....	9
Hydraulic Conductivity .....	9
Hydraulic Gradient .....	10
Design Flow .....	12
Mixing Zone Thickness .....	12
Lot Layout Parameters .....	12
Parcel Imperviousness .....	13
Natural Recharge Rate .....	13
Background Nitrate Concentration.....	13
Septic Tank Effluent Concentration .....	14
Mass Balance Spreadsheet Results .....	14
Pathogen Transport Analysis .....	16
Phosphorous Transport Analysis.....	16
Conclusion .....	16
References.....	16
Appendix A : EIPH Letter Report .....	A-1
Appendix B : Well Driller Reports.....	B-1
Appendix C : Soil Resources .....	C-1
Appendix D : Nutrient Mass Balance Spreadsheets.....	D-1
Appendix E : Potentiometric Mapping Data .....	E-1

**FIGURES**

Figure 1: Subdivision Vicinity Map ..... 1

Figure 2: Subdivision Layout ..... 1

Figure 3: Area of Well Driller Report Compilation ..... 2

Figure 4: Topographic Map of Area of Review..... 5

Figure 5: Project Site Soil Survey Excerpt ..... 6

Figure 6: Surface Geology ..... 7

Figure 7: Nitrate Samples Near Project Vicinity..... 8

Figure 8: Hydraulic Conductivity Information from Nicklin (2003) ..... 10

Figure 9: Area Topography from Teton County GIS ..... 11

Figure 10: Hydraulic Gradient of 0.9% Estimate from nearby Well Logs ..... 12

Figure 11: Annual Precipitation Information..... 13

**TABLES**

Table 1: Result Summary from IDWR Find a Well Map in the Area of Review ..... 3

Table 2: Soil Characteristic Summary ..... 6

Table 3: Nitrate Concentration Results ..... 14

# INTRODUCTION

The purpose of this document is to fulfill the requirements of a Level I Nutrient Pathogen Study to investigate the potential impacts on groundwater and surface water from on-site wastewater treatment systems. The project site is called JC Ranches Subdivision, owned by JD ID WY LLC. It is located in the northeast of the northeast and the northwest of the northeast quarter quarters of section 10 of T. 5 N. and R. 45 E., B.M. in Teton County Idaho and the parcel ID is RP05N45E101000.

The proposed project is for the subdivision of a 79.1-acre parcel of land. The parcel zoning at the time of the concept plan approval is "Agriculture/Rural Residential-2.5-Acre Min. Lot Size". The project as proposed is to subdivide the parcel into 26 lots. The parcel is bisected by Leigh Creek Canal. According to the Teton County GIS, irrigation in the parcel area is controlled by the Grand Teton Canal Company. Eight lots are located on parcel acreage on the west side of the canal. This area comprises 25.0 acres. Lot areas range from 2.51 to 5.88 acres with an average size of 3.12 acres. The other 18 lots are located on the east side of the irrigation canal. Those lots range in size from 2.51 to 6.46 acres. The average lot size is 3.01 acres with a total area of 54.1 acres. Lot 17 will not have housing developed. It will instead be used for the fire pond and open space. Please see the following figures for the vicinity map and proposed subdivision layout.




Figure 1: Subdivision Vicinity Map




Figure 2: Subdivision Layout

To start the subdivision process, Y2 on behalf of JD ID WY LLC, had a pre-application meeting in December of 2021. A concept plan for the subdivision was submitted in February of 2022. A concept plan review was prepared by Teton County and a public hearing was held on April 12, 2022. Eastern Idaho Public Health (EIPH) completed field observations of test holes and provided a preliminary approval letter of the subdivision dated June 28, 2022.

The EIPH preliminary approval also summarized on site soil findings from three test pits excavated on site. Recommendations for the types of septic systems for the three different test pit areas were provided as well. The test hole locations are shown in Figure 2. Test holes were only completed on the west portion of the property due to the canal flowing and inaccessibility to the eastern portion. However, the EIPH letter did not express concern over this since the soil conditions do not change across the site significantly.

There was no groundwater or bedrock encountered in any of the test holes. Test hole #1 had fine sandy loam that varied in thickness and then transitioned to gravelly sandy loam down to 10 feet below the ground surface (bgs). Test hole #2 was excavated down to 120" and comprised of sandy silty loam. Past the 36" depth, the soil was more of sandy gravel with 40-50% rock content. Test hole #3 was mostly sandy silty loam down to 10" bgs and then more gravel and fine sand were encountered. Leach fields are to be sized according to a B1 soil type due to the presence of rocks in lower layers and a loamy sand soil type. The report from EIPH is included in Appendix A in its entirety of this report.

The proposed site lies partially within the Wetland Overlay area and therefore a Level I Nutrient Pathogen (NP) Evaluation is required Per Subdivision Regulations of Teton County, Idaho, Title 9, Section 9-3-2-C-3-b-i-a. The following sections provide information to meet the minimum required elements for an NP evaluation.

## **WELL DRILLER REPORTS**

Per Appendix A of Title 09, Nutrient-Pathogen Evaluation Technical Guide for On-Site Wastewater Treatment Systems in Teton County, Idaho (referred to as Guide from now on in this submittal), the first of the minimum requirements is to provide well driller reports within ½ mile of the project site. See Figure 3 for the area for which well driller reports were researched and cataloged.




Figure 3: Area of Well Driller Report Compilation

The search area was all within T. 05 N. and R. 45 E. B.M. in Teton County. All of section 10 was included except for the southernmost row of quarter-quarters. The Northwest quarter of section 11 was included as well as the north half of the Southwest quarter. The south half of section 3 and the southwest quarter of section 2 was included in the search area.

A total of 29 wells were found within the area of review. Where well use was listed, it was for domestic, most of which were listed as a single residence.

Table 1: Result Summary from IDWR Find a Well Map in the Area of Review

Permit ID	Metal Tag #	Construction Date	Section	Quarter - Quarter	Production Rate (gpm)	Static Water Level (ft bgs)	Casing Diameter (in)	Casing Depth (ft)	Total Depth (ft)
<b>Section 2 Wells</b>									
772451	D0021957	12/21/2001	2	NWSW		80	6	180	184
837999	D0037968	1/5/2006	2	NWSW	20	46	6	99	100
<b>Section 3 Wells</b>									
769608	D0021179	6/24/2001	3	NESE	30	17	6	79	80
703066	D0004108	8/7/1997	3	NESE	30	8	6	80	
702564		9/30/1994	3	NESE	30	25	6	80	
800174		5/31/1962	3	NESW		11	16	139	142
895620	D0083626	8/30/2020	3	NESW	35	10	6	100	100
780854	D0024649	7/16/2002	3	NESW	20	73	6	120	120
703039		7/6/1997	3	NESW	30	60	6	100	100
897398	D0084046	1/28/2021	3	NWSE	20	38	6	118	120
894735	D0081943	7/6/2020	3	NWSE	15	28	6	120	120
887264	D0075647	8/23/2018	3	NWSW		10	6	98	98
769242	D0021012	5/29/2001	3	SESE		35	6	84	84
878801	D0068770	5/23/2016	3	SESE		24	6	98	100
701985		8/20/1991	3	SESW	50	15	6		85
702847		5/13/1996	3	SESW	30	64	6	100	100
702556		9/17/1994	3	SESW	35	15	6	60	60
897773	D0084048	3/9/2021	3	SWSE	15	40	6	98	100
886148	D0075610	5/30/2018	3	SWSE		30	6	98	100



Permit ID	Metal Tag #	Construction Date	Section	Quarter - Quarter	Production Rate (gpm)	Static Water Level (ft bgs)	Casing Diameter (in)	Casing Depth (ft)	Total Depth (ft)
<b>Section 3 Wells Continued</b>									
838116	D0037981	1/23/2006	3	SWSE	20	46	6	99	100
702232		4/28/1993	3	SWSW	50	105	6	152	152
822910		3/14/1977	3	SWSW		23	6	60	60
702846		5/12/1996	3	SWSW	40	32	6	100	100
<b>Section 10 Wells</b>									
849279	D0048827	10/1/2007	10	NWNE		20	6	100	100
826174	D0035757	4/27/2005	10	NWSW		35	16	116	140
<b>Section 11 Wells</b>									
833585	D0035642	5/26/2005	11	NESW		35	6	100	100
814333		3/27/1982	11	NESW		80			95
840958	D0044152	7/17/2006	11	SENE	30	56	6	100	100
901596	D0089363	8/19/2021	11	NWNW	15	40	6	115	115

*(Intentionally Left Blank)*

## SECTION 2 WELL SUMMARY

There are two wells listed in section 2. They both have drilling logs associated with them. One well was constructed in 2001 and was drilled down to 184 feet and had a static water level of 80 feet. The other well was constructed in 2006 and was drilled to 100 feet with a static water level of 46 feet. There is mixed clay, gravel, and sand in the soil profile. The deeper well encountered broken rhyolite mixed with clay at 170' bgs.

## SECTION 3 WELL SUMMARY

There are 21 wells within this section, which makes up the majority of the wells within the area of review. The shallowest static water level was at 8 feet and the deepest was at 105 feet below the ground surface. These wells show the general lithology in the area is mostly made up of sand, gravel, and clay.

## SECTION 10 WELL SUMMARY

Section 10 has two wells located in the area of review, one was drilled in 2005 and the other in 2007. The 2007 well appears to be installed on the project property. One of the logs encountered mainly clay and gravel with some sand mixed in throughout the middle of the log. The other log encountered gravel and sand in the shallower depths and then started to encounter some larger gravels from 100 to 140 feet bags. One well had a static water level of 20 feet and the other was 40 feet.

## SECTION 11 WELL SUMMARY

This section has four wells. One of the wells does not have a drilling log associated with it and it was constructed in August 2021. The other three wells have drilling logs associated with them. The static water level of these three wells ranges from 35 feet to 80 feet. All of these wells were drilled to a total depth of around 100 feet. Each lithologic log encounters some gravel, sand, and clay, with the gravel being encountered at the beginning and end, and the clay and sand being encountered around the middle of the log.

## OVERALL WELL LOG AND TOPOGRAPHY OBSERVATIONS




Figure 4: Topographic Map of Area of Review

The general topography in the project site area is sloping down from east to west and slightly south. The project site slopes at approximately 1 to 2%. The eastern side of the project property has an elevation of a little less than 6140 feet and the western end has an elevation ranging from about 6110 down to 6105 feet. There is also a canal that runs diagonally from the northeast corner to the southwest corner of the property.

There is only one well that is downgradient of most of the site and it is on the property itself. The well is located in the NWNE, is 100 feet deep, and the static water level is 20 feet bags.

## SOIL AND SURFACE GEOLOGIC CONDITIONS

The United States Department of Agriculture (USDA) Natural Resources Conservation District (NRCS) soil survey for the project area was utilized to supplement the information on soils in the area. A summary of site soil is presented below. The entire soil survey is included in Appendix C



Figure 5: Project Site Soil Survey Excerpt

Table 2: Soil Characteristic Summary

Soil Map Unit Number	Soil Group Name	Soil Description
13101	Redfish-Foxcreek complex, 0 to 2 percent slopes	Mucky peat on the surface underlain by loam progressing to extremely gravelly coarse sand. Soil Group C/D.
13113	Foxcreek mucky peat, 0 to 2 percent slopes	Mucky peat on the surface underlain by loam progressing to extremely gravelly coarse sand. Soil Group C/D.
13430	Alpine – St. Anthony complex, 0 to 2 percent slopes	Gravelly loams progressing to gravel. Well Drained. Soil Group B.
13431	Feltonia-Arimo complex 0 to 2 percent slopes	Loam, progressing to a very gravelly loamy sand. Well Drained. Soil Group B/C.

According to the area geologic map, the project is located in the East Teton Basin, which is influenced by Leigh Creek and Tributaries. The project area map unit is Q1/Qf which are alluvial fan deposits from the Holocene to Late Pliocene area. The specific map unit means it is overlain by loess. This is a gravel and silt mixture said to be formed by a large flood of Leigh Creek. Please see the excerpt below. The entire geologic map is included in Appendix C.



Figure 6: Surface Geology

## BACKGROUND NITRATE CONCENTRATION

The Idaho Department of Environmental Quality (IDEQ) 2020 Nitrate Priority Area GIS server was used to determine nearby background nitrate concentrations. The figure below illustrates the nearby sample points. To the north, there are two sample points which are 0.27 and 0.73 mg/L. There are many sample points to the east of the project site, and they have a wide range of values, ranging from 0.18 to 3.44 mg/L Nitrate. The samples located south of the project site have a range from 1.44 to 3.12 mg/L of Nitrate. There is one sample point that is located southwest of the project site, and it has the highest value of 7.87 mg/L.

*(Intentionally Left Blank)*




Figure 7: Nitrate Samples Near Project Vicinity

# NITROGEN MASS BALANCE SPREADSHEET


Different combinations of lots were analyzed in order to see if the Nitrogen Mass Balance Spreadsheet exhibits an increase of 1 mg/L Nitrate. The following iterations were ran:

- Each individual lot.
- Lots 1-8
- Lots 9-26

It was found that due to the site layout and the direction of groundwater flow (discussed in the Hydraulic Gradient below) that other combinations of lots did not make sense. The irrigation ditch runs from northeast to southwest through the property, roughly parallel to the groundwater flow direction. Therefore, the east and west sides of the subdivision are assumed to behave separately as the ditch acts as a model boundary. If the northeast lot on either side of the ditch is taken as a starting point, following the gradient, it ends up including all the lots on that side. When all of the lots are included on either the east or west sides of the ditch, this is the most conservative scenario for the nutrient pathogen evaluation. So, the proposed lot combinations appear reasonable. A summary of the input values is provided below. The individual mass balance sheets are included in Appendix D.

## HYDRAULIC CONDUCTIVITY

The onsite test pits excavated exhibit a soil classification of poorly sorted sand (SP). Some gravel and very few fines were observed in the proposed leachfield areas. This on-site excavation indicates a relatively permeable soil. Drilling logs, soil survey, and geology for the project site all demonstrate sand and gravel with some silts and clays. Per the Nicklin (2003) report assigned shallow hydraulic conductivity, we have used 80 feet per day in this analysis. In the same report in the project area, there was also an assignment of over 150 feet per day, but the lower, more conservative value was used for this analysis.






Figure 8: Hydraulic Conductivity Information from Nicklin (2003)

## HYDRAULIC GRADIENT

The final report: Ground-Water Model for the Upper Teton Watershed by Nicklin Earth & Water, Inc. dated March of 2003 has often been used for this parameter. This is an excellent study of the groundwater system for the entire Upper Teton Watershed. However, this study was not designed to provide site specific data for NP Evaluations. Y2 feels that it is appropriate to use this document as a general guideline for the direction of groundwater flow as well as the general magnitude of the slope of the groundwater surface. However, groundwater models, especially of the size of this one, can only be calibrated and expected to operate within an order of magnitude of accuracy.

In order to take a closer look at the hydraulic gradient, we have taken the groundwater levels that were used in the report to set up a general area for study. We created a potentiometric map of the groundwater in the subdivision area. This map was to go as far west as the Teton River to see how groundwater levels are trending in that direction. Water levels were utilized from the Idaho Department of Water Resources (IDWR) well database.

It is recognized that this data source has its limitations. Drillers do not log static water level data with the purpose of using that data for future groundwater modeling efforts in mind. Also, these wells are drilled at different times of the year, throughout different years. Finally, the NP Evaluation is assessing impacts on the shallow aquifer because this is where degradation to groundwater would first occur. Many of the wells are focused on deeper aquifer units so the well reliably productive over a long period of time and not subject to the variability that can be seen in a very shallow aquifer.

To help balance these imperfections of the data, parameters for well selection were limited to try and create a more uniform and reasonable potentiometric surface that has additional detail over what as in the Nicklin report:

1. Like the Nicklin report, wells drilled prior to 1990 were not used.

2. IDWR has a lot of data and wells in the project vicinity. Many of the newer wells are within subdivisions. Well parameters had patterns in these subdivisions that led to water level mapping that was based on several data points (instead of one) and an average of those water levels were used in the potentiometric map.
3. In areas with groups of wells, there would be some with shallow groundwater levels (30 feet below ground surface or less), and those that were relatively deep (over 60 feet deep). Since the shallow aquifer is of interest, shallower groundwater levels were utilized. This keeps in line with the 15-foot mixing zone thickness in the mass balance spreadsheet and is more conservative.

It was found in this exercise that shallow groundwater levels very closely parallel the slope of the ground surface. This is to be expected and the topographic slope was used in the first iteration of the study. The shallow groundwater levels range from 10 to 20 feet bgs in most areas. When a groundwater well is located adjacent to a surface water feature, the water level dropped below 10 feet to as shallow as 4 feet bgs. The following images from the Teton County GIS system with contours and measurements show the change in ground slope as we proceed west of the site toward the Teton River. At the project site the topographic slope is approximately 1%, which has been confirmed by our onsite survey. As we proceed about a mile west, the slope decreases to about 0.7%. The groundwater surface followed this same general trend but is sloping a little less steep than the ground and continues to get less steep the closer and closer we get to the River. One USGS well elevation from the Nicklin report, which is west of the river, shows that the groundwater slope likely changes direction at the River.




Figure 9: Area Topography from Teton County GIS



The results from the potentiometric mapping are shown below. Individual well points around the project site result in slopes varying from 0.8% to just shy of 2.0%. Averaging these slopes up and down gradient of the site result in a hydraulic gradient of 0.9%.




Figure 10: Hydraulic Gradient of 0.9% Estimate from nearby Well Logs

Y2 proposes to use a groundwater slope of 0.9% for the mass-balance spreadsheets. Additional information showing how the average slope across the site was estimated, along with notes and the drilling logs used to map the groundwater surface are provided in Appendix E.

## DESIGN FLOW

The 300 gallon per day per household default parameter value was used for the design flow. Each lot will be allowed to have a home and an attached accessory dwelling unit. The CCRs and the Plat will limit the allowed total bedrooms per lot to 6 for the primary and accessory dwelling unit. Per Idaho Administrative Procedures Act (IDAPA) 58.01.03.007.08 a single-family dwelling unit design flow rate is 50 gallons per day per bedroom.

## MIXING ZONE THICKNESS

The default mixing zone thickness was used for all the lots.

## LOT LAYOUT PARAMETERS

The site flows from east to west, with a slight tilt towards the south. For each lot and combination of lots laid out above, the distance perpendicular to flow was measured using the lot lines and the gradient depicted in Figure 10.

## PARCEL IMPERVIOUSNESS

The west half of the development has an average lot size of 3.12 acres. The east half has an average lot size of 3.01 acres. A relatively large house, outbuildings, and an access drive are assumed to use a maximum of 6,000 square feet for each lot. This results in an imperviousness of between 4 and 5%. A value of 5% was used in the spreadsheets.

## NATURAL RECHARGE RATE

The natural recharge rate was calculated as 1.65 inches per year from the natural recharge rate calculation in the spreadsheet. The average annual precipitation amount according to the Tetonia Experiment Station is 18.96 inches per year.




Figure 11: Annual Precipitation Information

## BACKGROUND NITRATE CONCENTRATION

The background nitrate concentration of 3.4 mg/L was used from the data point east of the site from the IDEQ 2020 Nitrate Priority Area GIS server. This was the highest value from the upgradient sample points.

## SEPTIC TANK EFFLUENT CONCENTRATION

The density and layout of the proposed subdivision does not lend itself well to a conventional septic system and still meet nitrogen loading criteria. It is therefore proposed that each lot have an Advanced Septic System installed to reduce nitrate loading on the groundwater. Extended Treatment Package Systems (ETPS) manufacturer’s report have nitrogen tank effluent concentrations ranging from under 10 up to 20 mg/L. This is a vast improvement over the typical septic tank nitrogen treatment, which only reduces nitrogen by 2-10% down to around 45 mg/L, mostly by trapping it in the scum and solids that are removed when a tank is pumped (Washing DOH 2014). Advanced Septic Systems will be required in the subdivision CCRs and the plat to ensure protection of groundwater.

While these systems can attain 20 mg/L or better effluent quality, the purpose of the Level I study is to provide a conservative screening to ensure that nitrate concentration increases are limited to 1 mg/L at the study area boundary. Therefore, an effluent limit of 32 mg/L was used in the mass balance spreadsheets. This value is supported by the IDEQ Nutrient-Pathogen Evaluation Program for On-Site Wastewater Treatment Systems modeling default parameters for enhanced nutrient treatment systems.

## MASS BALANCE SPREADSHEET RESULTS

The summary of the downgradient nitrate concentration of each lot is shown in the table below.

Table 3: Nitrate Concentration Results

Lot #	Downgradient Nitrate Concentration (mg/L)	≤1 mg/L Nitrate Increase?	Lot #	Downgradient Nitrate Concentration (mg/L)	≤1 mg/L Nitrate Increase?
1	3.7	Yes	15	3.7	Yes
2	3.7	Yes	16	3.7	Yes
3	3.7	Yes	17	3.3 – Fire Pond	Yes
4	3.7	Yes	18	3.7	Yes
5	3.7	Yes	19	3.7	Yes
6	3.6	Yes	20	3.7	Yes
7	3.7	Yes	21	3.8	Yes
8	3.5	Yes	22	3.8	Yes
9	3.6	Yes	23	3.8	Yes
10	3.6	Yes	24	3.8	Yes
11	3.6	Yes	25	3.8	Yes
12	3.6	Yes	26	3.8	Yes
13	3.6	Yes	1-8	4.1	Yes
14	3.7	Yes	9-26	4.4	Yes

## PATHOGEN TRANSPORT ANALYSIS

According to Appendix A, Nutrient-Pathogen Evaluation Technical Guide for On-Site Wastewater Treatment Systems in Teton County, Idaho “pathogen transport modeling cannot be done with enough certainty to be useful”. However, septic systems, by design are very effective at removing pathogens from the wastewater stream prior to water migrating into the aquifer. A properly maintained system will develop a biomat in the leachfield which prevents migration of pathogens off site.

## PHOSPHOROUS TRANSPORT ANALYSIS

Phosphorus is the chemical of concern when assessing impacts to surface water bodies. Additional phosphorus can lead to excessive vegetation and algae growth that lowers the oxygen in the surface water body. This leads to fish die off and an overall decrease in water quality. The irrigation canal bisecting the subdivision would be the nearest water body that could be affected by Phosphorus concentrations. However, being that it is an irrigation canal for water crops, Phosphorus is less of a concern than if it were a stream that housed aquatic life. The Nitrogen analysis demonstrates that nitrate increases from the development will be held to less than 1 mg/L increase. Phosphorus, even assuming no treatment from the septic system, will be similarly diluted and not decrease groundwater or surface water quality.

## CONCLUSION

The proposed layout of the JC Ranches Subdivision will not degrade groundwater. Our findings are that the soil is suitable for traditional septic systems as laid out in the letter from EIPH. In addition, the lots with the Advanced Septic Systems are large enough to provide adequate distance between wastewater and water systems to protect the health and safety of the future users of the subdivision and adjacent landowners.

## REFERENCES

- Idaho Administrative Procedures Act (IDAPA). 58.01.03 – Individual/Subsurface Sewage Disposal Rules. IAC. 2006.
- Idaho Department of Environmental Quality. July 14, 2021. 2020 Nitrate Priority Areas. <https://mapcase.deq.idaho.gov/npa/>.
- Idaho Department of Environmental Quality. May 6, 2002. Nutrient-Pathogen Evaluation Program for On-Site Wastewater Treatment Systems.
- Idaho Department of Water Resources. Find a Well Map. June 28, 2022. <https://idwr.idaho.gov/wells/find-a-well-map/>
- National Oceanic and Atmospheric Administration. July 14, 2022. <https://www.ncdc.noaa.gov/cdo->
- Nicklin Earth & Water, Inc. Ground-Water Model for the Upper Teton Valley Watershed. 2003.
- Embree, Glenn F. Geologic Map of the Clawson Quadrangle, Teton County, Idaho. 2014.
- Teton County Code. Title 09 Subdivision Regulations. 2013.

Teton County Online Geographic Information System. July 15, 2022.

<https://tetonidaho.maps.arcgis.com/apps/webappviewer/index.html?id=7cad88173b644a6a8e8c1147e94aa524>.

United States Department of Agriculture, Natural Resources Conservation District. Custom Soil Resource Report for Teton Area, Idaho, and Wyoming JC Ranches Subdivision. Downloaded September 6, 2022.

Washington Department of Health. How Nitrogen from Septic Systems Can Harm Water Quality. August 2014.

# Appendix A: EIPH LETTER REPORT

06/28/2022  
Teton County Planning and Zoning  
89 North Main Suite 6  
Driggs, Idaho 83422

Jim Herbert  
4750 S Cortland Drive  
Jackson, WY 83001

Re: JC Ranches Subdivision

I have reviewed the application to have RP05N45E101000 subdivided into twenty-five (25)) lots to be known as JC Ranches Subdivision and determined the parcel and proposed lots are suitable for sub-surface waste disposal systems to serve residences.

Soil information observed is consistent across the parcel and is as follows:  
0-48 inches of fine sandy loam topsoil with minor rock content. B1 Soil Type. The thickness of this layer varies across the property ranging from 10 inches up to 48 inches. Minor rock content. Below the top soil layer to depth of 120 inches lies very gravelly fine to medium sandy loam with up to 65% rock content. Rock content has slight increase with depth. Rounded clasts range from .5 to 5 inches diameter. A2b Soil Type.  
No groundwater evidence was seen any test hole. No bedrock was encountered to a depth of 120 inches.

The parcel is cut diagonally by an irrigation canal/ditch. Due to deep fast water the eastern portion was not accessible. The soil horizon and rock content will not change from that observed in the western portion of the property. Adjacent properties to the south and east have been evaluated and have the same soil types and horizons. All areas of the parcel are suitable for sub-surface wastewater disposal systems. All drainfields should be sized using B1 application rate of 0.6 gpd/sq ft due to the rock content in the lower layer.

The parcel has a very minor slope from the Northeast to the southwest.

Eastern Idaho Public Health gives preliminary approval of the application to divide RP05N45E101000 creating the JC Ranches Subdivision. The site is suitable for residential sub-surface waste disposal. Individual subsurface sewage disposal systems may be allowed in accordance with IDAPA 58.01.03 and the Technical Guidance Manual for Individual Subsurface Waste Disposal. All current Idaho Rules must be met. Suitability criteria and required separation distances are to be maintained.


A copy of the final plat is to be provided to the Health District at the time the Health Certificate is signed. The application fee balance if any will also be collected prior to signing the Health Certificate. If this application /plan changes for any reason, please coordinate those changes in advance, with this office.



Kathleen Price  
REHS/MSG  
Eastern Idaho Public Health District  
kprice@eiph.idaho.gov  
208-354-2220








INVENT PARCEL  
80.25 ACRES  
LOCATED IN  
SECTION 10, TOWNSHIP 5 N  
RANGE 45 EAST, B.M.  
TETON COUNTY, IDAHO



<b>MAP 1</b> CONCEPT PLAN	<b>SUBDIVISION APPLICATION</b> <b>JC RANCHES SUBDIVISION APPLICATION</b> 80.25 ACRES WITHIN SEC 10, TOWNSHIP 5 NORTH, RANGE 45 EAST, B.M. TETON COUNTY IDAHO	 <b>Y2 CONSULTANTS</b> ENGINEERING, SURVEYING & PLANNING 207 S. 12TH ST. BOISE, IDAHO 83725	DRAWING SET TITLE SUBDIVISION APPLICATION DRAWN BY: BPH CHECKED BY: BPH JOB #: 2-108-03

**SUBDIVISION ON-SITE**

Conducted on: June 2022 Time: Travel \_\_\_\_\_ On-site \_\_\_\_\_

I. NAME OF SUBDIVISION: JC Ranches

II. LOCATION (COUNTY): Teton

III. GENERAL INFORMATION:

A. Current Land Use: Ag/Pasture

B. Adjoining Property Use: Same as above / Residential

C. Surface Water (on or near development): Irrigation Canal/Ditch -

D. Slope: Minor to None

E. Drainage Areas Present: No

F. Rock Outcrop Present: No

G. Wetland Indications: No County has designated small amount

IV. EVALUATION: of property as wetland, but this is Ag wetland/flood irrigator.

A. Individual water and sewer:  
Does each lot appear to have sufficient area to install proposed system and to meet minimum separation requirements? Yes X No \_\_\_\_\_

B. Individual water and central sewer:  
Does there appear to be sufficient area for central system and replacement area? Yes \_\_\_\_\_ No \_\_\_\_\_

C. Individual sewer and central water system:  
Does each lot appear to have sufficient area to install proposed system and to meet minimum separation requirements? Yes \_\_\_\_\_ No \_\_\_\_\_

D. Individual sewer and public water system:  
Does each lot have sufficient area to install proposed system and to meet minimum separation requirements? Yes \_\_\_\_\_ No \_\_\_\_\_

COMMENTS:  
No problems w/ suitability for septic systems. 50' separation from irrigation ditch required from any portion of septic system.

EHS: [Signature]

## TEST HOLE INFORMATION

SUBDIVISION JC Ranches DATE \_\_\_\_\_

~ 60' from canal/ditch

Test Hole # 1

Test Hole # 2

Test Hole # 3

Location: Between Lot 1 + 5




Location: Lot 7

Location: NE corner lot 3

Depth: 120"

Depth: 120"

Depth: 120"



- Unable to cross Ditch to eastern portion of site

Test Hole # \_\_\_\_\_

Test Hole # \_\_\_\_\_

Test Hole # \_\_\_\_\_

Location: \_\_\_\_\_




Location: \_\_\_\_\_

Location: \_\_\_\_\_

Depth: \_\_\_\_\_

Depth: \_\_\_\_\_

Depth: \_\_\_\_\_



# Appendix B: WELL DRILLER REPORTS

IDAHO DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Office Use Only		
Inspected by _____	_____	
Twp _____	Rge _____	Sec _____
_____ 1/4	_____ 1/4	_____ 1/4
Lat: : : _____	Long: : : _____	

**1. WELL TAG NO. D** ~~0021957~~ 0021957  
**DRILLING PERMIT NO.** 772451  
 Other IDWR No. \_\_\_\_\_

**2. OWNER:**  
 Name Sean & Lori Collins  
 Address PO Box 589  
 City Driggs State Id Zip 83422

**3. LOCATION OF WELL by legal description:**

Sketch map location must agree with written location.

N		Twp. <u>5</u> North <input checked="" type="checkbox"/> or South <input type="checkbox"/>	
W		Rge. <u>45</u> East <input checked="" type="checkbox"/> or West <input type="checkbox"/>	
E		Sec. <u>2</u> NW 1/4 SW 1/4 _____ 1/4	
S		Gov't Lot _____ County <u>Teton</u> 10 acres 40 acres 160 acres	
		Lat: : : _____ Long: : : _____	
Address of Well Site _____			
<u>(4 Peaks)</u>		City <u>Driggs</u>	
<small>(Give at least name of road - Distance to Road or Landmark)</small>			

Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name Pack saddle Estates

**4. USE:**

- Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

**5. TYPE OF WORK** check all that apply (Replacement etc.)

- New Well  Modify  Abandonment  Other \_\_\_\_\_

**6. DRILL METHOD**

- Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

**7. SEALING PROCEDURES**

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0'	20'	600 lbs	OVER BORE

Was drive shoe used?   N Shoe Depth(s) \_\_\_\_\_  
 Was drive shoe seal tested?   N How? \_\_\_\_\_

**8. CASING/LINER:**

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+18"	180'	250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

**9. PERFORATIONS/SCREENS**

Perforations \_\_\_\_\_ Method \_\_\_\_\_  
 Screens \_\_\_\_\_ Screen Type \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

**10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:**

80 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
 Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: well cap

**11. WELL TESTS:**

- Pump  Bailer  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_

Water Quality test or comments: \_\_\_\_\_

Depth first Water Encounter \_\_\_\_\_

**12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water**

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10"	0'	3'	Top soil		
	3'	20'	Brown Clay & Gravel		
6"	20'	170'	Brown Clay & Gravel		
	170'	184'	Broken Zyalite & Gravel	X	

RECEIVED

APR 10 2002

Department of Water Resources

RECEIVED

FEB 26 2002

Department of Water Resources  
Eastern Region

Completed \_\_\_\_\_ Depth 184 ft (Measurable)  
 Date: Started 12-17-01 Completed 12-22-01

**13. DRILLER'S CERTIFICATION**

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Martins Well Service Firm No. 478

Firm Official [Signature] Date 12-31-01

and Driller or Operator \_\_\_\_\_ Date \_\_\_\_\_

(Sign once if Firm Official & Operator)

IDAHO DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

22

Office Use Only			
Well ID No.	_____		
Inspected by	_____		
Twp	Rge	Sec	
_____	_____	_____	
_____	1/4	1/4	1/4
Lat: : : :	Long: : : :		

1. WELL TAG NO. D 0037968  
 DRILLING PERMIT NO. \_\_\_\_\_  
 Water Right or Injection Well No. \_\_\_\_\_

2. OWNER:  
 Name Quality Construction  
 Address 3780 Taylor View  
 City Idaho Falls State Id Zip 83401

3. LOCATION OF WELL by legal description:  
 You must provide address or Lot, Blk, Sub. or Directions to well.  
 Twp. 6 North  or South   
 Rge. 45 East  or West   
 Sec. 32 1/4 SW 1/4 JW 1/4  
 Gov't Lot \_\_\_\_\_ County Latah  
 Lat: : : Long: : :  
 Address of Well Site 407 Los Pinos City Driggs  
 Lt. 3 Blk. \_\_\_\_\_ Sub. Name Los Pinos

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>150</u>	<u>Over Base</u>

Was drive shoe used?  Y  N Shoe Depth(s) 99'  
 Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6</u>	<u>71</u>	<u>99</u>	<u>200</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
 Packer  Y  N Type \_\_\_\_\_

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method \_\_\_\_\_  
 Screen Type & Method of Installation \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
46 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
 Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

12. WELL TESTS:  
 Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>20 +</u>	<u>450</u>	<u>@ 550</u>	<u>1 hr</u>

Water Temp. Cool Bottom hole temp. 60.1  
 Water Quality test or comments: \_\_\_\_\_

13. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>6</u>	<u>0</u>	<u>20</u>	<u>Sand &amp; gravel</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>6</u>	<u>20</u>	<u>70</u>	<u>Clay &amp; gravel</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>6</u>	<u>70</u>	<u>100</u>	<u>Brown clay</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>6</u>	<u>70</u>	<u>100</u>	<u>Clay &amp; gravel</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

RECEIVED  
 JAN 26 2006  
 Department of Water Resources  
 Eastern Region

Completed Depth 100' (Measurable)  
 Date: Started 1-4-06 Completed 1-6-06

14. DRILLER'S CERTIFICATION  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Mark Mitchell well dr Firm No. 2612  
 Principal Driller [Signature] Date 1-26-06  
 and  
 Driller or Operator II \_\_\_\_\_ Date \_\_\_\_\_  
 Operator I \_\_\_\_\_ Date \_\_\_\_\_

Principal Driller and Rig Operator Required.  
 Operator I must have signature of Driller/Operator II.

# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only		
Inspected by	_____	
Twp	Rge	Sec
1/4	1/4	1/4
Lat: _____	Long: _____	_____
<input type="checkbox"/> Pump	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Air <input type="checkbox"/> Flowing Artesian

1. WELL TAG NO. D 0021179  
 DRILLING PERMIT NO. 769608  
 Other IDWR No. \_\_\_\_\_

2. OWNER:  
 Name Christian Onufer  
 Address P.O. Box 3724  
 City Jackson State WY Zip 83001

3. LOCATION OF WELL by legal description:  
 Sketch map location must agree with written location.

N			
		X	
S			

Twp. 5 North  or South   
 Rge. 45 East  or West   
 Sec. 3 1/4 NE 1/4 SE 1/4  
 Gov't Lot \_\_\_\_\_ County Teton  
 Lat: \_\_\_\_\_ Long: \_\_\_\_\_  
 Address of Well Site \_\_\_\_\_  
 City \_\_\_\_\_

Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>5 Sacks</u>	<u>Annular</u>

Was drive shoe used?  Y  N Shoe Depth(s) -79  
 Was drive shoe seal tested?  Y  N How? A.I.

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6"</u>	<u>+1</u>	<u>-79</u>	<u>.28</u>	<u>STEEL</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

9. PERFORATIONS/SCREENS  
 Perforations \_\_\_\_\_ Method \_\_\_\_\_  
 Screens \_\_\_\_\_ Screen Type \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
17 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
 Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

11. WELL TESTS:  
 Pump  Bailer  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>30+</u>			

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
 Water Quality test or comments: \_\_\_\_\_  
 Depth first Water Encounter \_\_\_\_\_

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8"</u>	<u>0</u>	<u>20</u>	<u>Sand &amp; Gravel</u>		<input checked="" type="checkbox"/>
<u>6"</u>	<u>20</u>	<u>80</u>	<u>Sand &amp; Gravel</u>	<input checked="" type="checkbox"/>	

RECEIVED  
 AUG - 6 2001  
 RECEIVED  
 JUL 26 2001  
 Department of Water Resources  
 Eastern Region  
 Completed Depth 80' (Measurable)  
 Date: Started 6-21-2001 Completed 6-25-2001

13. DRILLER'S CERTIFICATION  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.  
 Company Name Independent Drilling Firm No. 343  
 Firm Official Brent Henderson Date 6-25-2001  
 and  
 Driller or Operator \_\_\_\_\_ Date \_\_\_\_\_  
 (Sign once if Firm Official & Operator)



# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen


68044

Office Use Only  
 Inspected by \_\_\_\_\_  
 Twp. \_\_\_\_\_ Rge. \_\_\_\_\_ Sec. \_\_\_\_\_  
 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4  
 Lat. : : : Long. : : :

1. DRILLING PERMIT NO. Tag # D000 - 4108  
Other IDWR No. 22-97E-0082-000

2. OWNER:  
Name Larry Reynolds  
Address P.O. Box 527  
City DRIGGS State ID Zip 83422

3. LOCATION OF WELL by legal description:  
Sketch map location must agree with written location.



Twp. 5 North  or South   
 Rge. 15 East  or West   
 Sec. 3 NE 1/4 SE 1/4 1/4  
 Gov't Lot \_\_\_\_\_ County Teton  
 Lat. : : Long. : :  
 Address of Well Site 1.35 Leigh Creek  
Estates City \_\_\_\_\_  
(Give at least name of road + Distance to Road or Landmark)

Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>200</u>	<u>over</u>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_  
Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6"</u>	<u>+1</u>	<u>20</u>	<u>280</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

9. PERFORATIONS/SCREENS  
 Perforations Method \_\_\_\_\_  
 Screens Screen Type \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
8 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

11. WELL TESTS:  
 Pump  Bailer  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>307</u>			<u>1 hr</u>

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
Water Quality test or comments: Good water  
Depth first Water Encountered \_\_\_\_\_

### 12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
	<u>0</u>	<u>3</u>	<u>top soil</u>		
	<u>3</u>	<u>62</u>	<u>sand &amp; gravel</u>	<input checked="" type="checkbox"/>	
	<u>62</u>	<u>64</u>	<u>clay &amp; gravel</u>		
	<u>64</u>	<u>80</u>	<u>gravel</u>	<input checked="" type="checkbox"/>	

RECEIVED  
AUG 20 1997

Department of Water Resources  
Eastern Region

RECEIVED  
MICROFILMED

AUG 26 1997

OCT 15 1997  
Department of Water Resources

Completed Depth 80 (Measurable)  
Date: Started 8-8-97 Completed 8-8-97

13. DRILLER'S CERTIFICATION  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.  
**TETON WATER WORKS LLC**  
 Firm Name Teton Water Works LLC Firm No. 506  
P.O. BOX 502  
SHELLEY ID 83274  
 Firm Official [Signature] Date 8-11-97  
 and  
 Supervisor or Operator [Signature] Date 8/11/97  
(Sign once if Firm Official & Operator)

WELL DRILLER'S REPORT

PERMIT ID 702564

Use Typewriter  
or  
Ball Point Pen

1. DRILLING PERMIT NO. 22-94-E-175-000  
Other IDWR No. \_\_\_\_\_

11. WELL TESTS: 55900  
 Pump  Bailer  Air  Flowing Artesian

2. OWNER:  
Name Keith Jones  
Address P.O. Box 1714  
City Murphy State Ca Zip 95247

Yield gal/min.	Drawdown	Pumping Level	Time
30	70	75	2 Hr

3. LOCATION OF WELL by legal description:  
Sketch map location must agree with written location.

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
Water Quality test or comments: Clear & good

Twp. 5 North  or South   
Rge. 45 East  or West   
Sec. 3 NE 1/4 SE 1/4 1/4  
Gov't Lot 32 County TETON

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
6	0	20	sand + gravel	X	X
	20	35	sand	X	X
	35	45	washed gravel	X	X
	45	60	clay + gravel	X	X
6	60	80	gravel	X	X

Address of Well Site \_\_\_\_\_  
City \_\_\_\_\_  
(Give at least name of road + Distance to Road or Landmark)

Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name Leigh Creek Estates

4. PROPOSED USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK  
 New Well  Modify or Repair  Replacement  Abandonment

6. DRILL METHOD  
 Mud Rotary  Air Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	20	2	Over Bone

Was drive shoe used? Y  N   
Was drive shoe seal tested? Y  N  How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	0	80	250	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

9. PERFORATIONS/SCREENS

Perforations Method NONE  
 Screens Screen Type \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

25 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

Completed Depth 80 (Measurable)  
Date: Started 10-1-94 Completed 10-1-94

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Teton water works Firm No. 506

Firm Official \_\_\_\_\_ Date 10-12-94

and  
Supervisor or Operator Richard [Signature] Date \_\_\_\_\_

(Sign once if Firm Official & Operator)

025222

WELL LOG AND REPORT OF THE  
STATE RECLAMATION ENGINEER OF IDAHO  
Permit ID 800174

Department of Reclamation

Permit No. \_\_\_\_\_ Well No. 1 County Teton

Owner Earl Spencer  
Idaho Falls, Idaho

Address \_\_\_\_\_

Driller R. P. Cope

Address 927 Poulsen Idaho Falls, Idaho

Well location S<sup>1</sup>/<sub>2</sub> 1/4 N<sup>1</sup>/<sub>2</sub> 1/4 Sec. 3, T. 5 N/S, R. 45 E/W

Size of drilled hole 16 inch

Total depth of well 142 ft.

Give depth to standing water from the ground 11 ft. Water temp. \_\_\_\_\_ °Fahr.

On "Pumping Test" delivery was \_\_\_\_\_ g.p.m. or \_\_\_\_\_ c.f.s. Drawdown was \_\_\_\_\_ feet.

Size of pump and motor used to make test \_\_\_\_\_

Length of time of test \_\_\_\_\_ hours \_\_\_\_\_ minutes.

If flowing well, give flow \_\_\_\_\_ c.f.s. or \_\_\_\_\_ g.p.m. and of shut off pressure \_\_\_\_\_

If flowing well, described control works \_\_\_\_\_  
(TYPE AND SIZE OF VALVE, ETC.)

Water will be used for Irrigation Weight of casing per lineal foot \_\_\_\_\_

Thickness of casing 1/4 in. Casing material Steel  
(STEEL, CONCRETE, WOOD, ETC.)

Diameter, length and location of casing 139 ft. of 16" O.D.  
(CASING 12" IN DIAMETER OR LESS, GIVE INSIDE DIAMETER;  
CASING OVER 12" IN DIAMETER, GIVE OUTSIDE DIAMETER)

CASING RECORD

Diam. Casing	From Feet	To Feet	Length	Remarks—seals, grouting, etc.

*WSP*

Number and size of perforations \_\_\_\_\_ located \_\_\_\_\_ feet to \_\_\_\_\_ feet from ground  
Perforated 133 ft.

Date of commencement of well May 1962 Date of completion of well May 1962

SN - 4SE - 3 S<sup>1</sup>/<sub>2</sub> N<sup>1</sup>/<sub>2</sub> (4585)



# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D0083626

Drilling Permit No. \_\_\_\_\_  
Water right or injection well # \_\_\_\_\_

2. OWNER: Scott Barlow

Name \_\_\_\_\_  
Address 27614 Robillard Springs Ln.  
City Katy State Tx Zip 77494

3. WELL LOCATION:  
Twp. 5 North  or South  Rge. 45 East  or West   
Sec. 3 10 acres 1/4 40 acres NE 1/4 160 acres SW 1/4

Gov't Lot \_\_\_\_\_ County Teton  
Lat. 43 ° 47.263 (Deg. and Decimal minutes)  
Long. 111 ° 07.910 (Deg. and Decimal minutes)  
Address of Well Site 1530 Leigh Creek Estates Rd  
City Tetonia

(Give at least name of road + Distance to Road or Landmark)  
Lot. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

5. TYPE OF WORK:  
 New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
<u>Bentonite</u>	<u>0</u>	<u>38</u>	<u>1100 LBS</u>	<u>10" temp casing</u>

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
<u>6</u>	<u>+1</u>	<u>100</u>	<u>250</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) 100

9. PERFORATIONS/SCREENS:  
Perforations  Y  N Method \_\_\_\_\_  
Manufactured screen  Y  N Type \_\_\_\_\_  
Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
Packer  Y  N Type \_\_\_\_\_

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

11. FLOWING ARTESIAN:  
Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

12. STATIC WATER LEVEL and WELL TESTS:  
Depth first water encountered (ft) 10 Static water level (ft) 10  
Water temp. (°F) \_\_\_\_\_ Bottom hole temp. (°F) \_\_\_\_\_  
Describe access port \_\_\_\_\_

Well test: \_\_\_\_\_ Test method:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
	<u>35</u>	<u>20</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (In)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
<u>10</u>	<u>0</u>	<u>10</u>	<u>Clay &amp; gravel</u>		<input checked="" type="checkbox"/>
<u>10</u>	<u>10</u>	<u>38</u>	<u>Clay &amp; gravel</u>	<input checked="" type="checkbox"/>	
<u>6</u>	<u>38</u>	<u>100</u>	<u>Clay &amp; gravel</u>	<input checked="" type="checkbox"/>	

RECEIVED  
SEP 28 2020  
Department of Water Resources  
Eastern Region

Completed Depth (Measurable): 100'  
Date Started: 8/31/20 Date Completed: 8/31/20

14. DRILLER'S CERTIFICATION:  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name: Daniel Danning Drilling Co. No. 518  
\*Principal Driller \_\_\_\_\_ Date \_\_\_\_\_  
\*Driller: Brand By Date 9/1/20  
\*Operator II \_\_\_\_\_ Date \_\_\_\_\_  
Operator I: Brand Piquet Date 9/1/20

\* Signature of Principal Driller and rig operator are required.



IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

68043

Permit ID 703039

Use Typewriter or Ballpoint Pen

Office Use Only  
 Inspected by \_\_\_\_\_  
 Twp \_\_\_\_\_ Rge \_\_\_\_\_ Sec \_\_\_\_\_  
 1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_  
 Lat: : : Long: : :

1. DRILLING PERMIT NO. 22-99-E-0055-000  
 Other IDWR No. \_\_\_\_\_

2. OWNER:  
 Name DAVE VANESSEN  
 Address HC 83  
 City Cascade State ID Zip 83611

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N					
S					

Twp. 5 North  or South   
 Rge. 45 East  or West   
 Sec. 3 NE 1/4 SW 1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_  
 Gov't Lot \_\_\_\_\_ County Teton  
 Lat: : : Long: : :  
 Address of Well Site \_\_\_\_\_ City DRIGGS  
 (Give at least name of road + Distance to Road or Landmark)

Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:

- Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)

- New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD

- Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>100</u>	<u>Overbore</u>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_  
 Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6" FOI</u>	<u>100</u>	<u>250</u>	<u>250</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

9. PERFORATIONS/SCREENS

- Perforations Method \_\_\_\_\_  
 Screens Screen Type \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

60 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
 Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

11. WELL TESTS:

- Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>30+</u>			<u>1 hr</u>

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_

Water Quality test or comments: \_\_\_\_\_

Depth first Water Encountered \_\_\_\_\_

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>6</u>	<u>0</u>	<u>6</u>	<u>Top Soil</u>		<input checked="" type="checkbox"/>
	<u>6</u>	<u>40</u>	<u>Sand &amp; Gravel, some Clay</u>	<input checked="" type="checkbox"/>	
	<u>40</u>	<u>87</u>	<u>Clay &amp; Gravel</u>	<input checked="" type="checkbox"/>	
	<u>87</u>	<u>90</u>	<u>Clay</u>	<input checked="" type="checkbox"/>	
	<u>90</u>	<u>100</u>	<u>Gravel</u>	<input checked="" type="checkbox"/>	

RECEIVED

JUL 30 1997

Department of Water Resources  
 Eastern Region

RECEIVED

MICROFILMED

AUG 08 1997

OCT 15 1997

Department of Water Resources

Completed Depth 100 (Measurable)  
 Date: Started 7/7/97 Completed 7/7/97

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Teton Water Works LLC Firm No. 504

Firm Official [Signature] Date 7-8-97

and

Supervisor or Operator [Signature] Date 7/7/97

(Sign once if Firm Official & Operator)





# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 0081943

Drilling Permit No. \_\_\_\_\_  
Water right or injection well # \_\_\_\_\_

**2. OWNER:**

Name Riverbend Builders  
Address 2810 Wood bridge  
City Idaho Falls State ID Zip 83402

**3. WELL LOCATION:**

Twp. 5 North  or South  Rge. 45 East  or West   
Sec. 3 1/4 NW 1/4 SE 1/4

Gov't Lot \_\_\_\_\_ County Teton  
Lat. 43 ° 47.144 (Deg. and Decimal minutes)  
Long. 111 ° 07.731 (Deg. and Decimal minutes)  
Address of Well Site 1901 Leigh Creeks Estate  
City Tetonia

Lot. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

**4. USE:**

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

**5. TYPE OF WORK:**

New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

**6. DRILL METHOD:**

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

**7. SEALING PROCEDURES:**

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
<u>Bentonite</u>	<u>0</u>	<u>40'</u>	<u>1100lbs</u>	<u>Temp Casing Overburden</u>

**8. CASING/LINER:**

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
<u>6"</u>	<u>+2'</u>	<u>120'</u>	<u>.250</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) 120'

**9. PERFORATIONS/SCREENS:**

Perforations  Y  N Method \_\_\_\_\_  
Manufactured screen  Y  N Type \_\_\_\_\_  
Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
Packer  Y  N Type \_\_\_\_\_

**10. FILTER PACK:**

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

**11. FLOWING ARTESIAN:**

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

**12. STATIC WATER LEVEL and WELL TESTS:**

Depth first water encountered (ft) 38' Static water level (ft) 28'  
Water temp. (°F) \_\_\_\_\_ Bottom hole temp. (°F) \_\_\_\_\_  
Describe access port \_\_\_\_\_

**Well test:**

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
<u>100'</u>	<u>15+ gpm</u>	<u>60 min</u>

**Test method:**

Pump	Bailer	Air	Flowing artesian
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

**13. LITHOLOGIC LOG and/or repairs or abandonment:**

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
<u>10"</u>	<u>0</u>	<u>20'</u>	<u>topsoil, gravel</u>		<u>N</u>
	<u>20'</u>	<u>40'</u>	<u>gravel, sand</u>	<u>Y</u>	
<u>6"</u>	<u>40'</u>	<u>60'</u>	<u>gravel, clay</u>	<u>Y</u>	
	<u>60'</u>	<u>80'</u>	<u>gravel, clay</u>	<u>Y</u>	
	<u>80'</u>	<u>100'</u>	<u>clay, gravel</u>	<u>Y</u>	
	<u>100'</u>	<u>120'</u>	<u>gravel</u>	<u>Y</u>	

RECEIVED  
AUG 13 2020  
Department of Water Resources  
Eastern Region

Completed Depth (Measurable): 120'  
Date Started: 7/6/20 Date Completed: 7/7/20

**14. DRILLER'S CERTIFICATION:**


I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Denning Drilling Co. No. 518  
\*Principal Driller Donald Denning Date 7-21-20  
\*Driller Ry Cook Date 7/8/20  
\*Operator II \_\_\_\_\_ Date \_\_\_\_\_  
Operator I Riley Hill Date 7/8/20

\* Signature of Principal Driller and rig operator are required.







*DMD*

STATE OF IDAHO  
DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

USE TYPEWRITER OR  
BALLPOINT PEN

State law requires that this report be filed with the Director, Department of Water Resources  
within 30 days after the completion or abandonment of the well.

**1. WELL OWNER** **Permit ID 701985**

Name Don Dabel

Address Star Route Box 343 Wilson

Owner's Permit No. 22-91-E-087 Wyoming

**7. WATER LEVEL**

Static water level 15' feet below land surface.

Flowing?  Yes  No G.P.M. flow \_\_\_\_\_

Artesian closed-in pressure \_\_\_\_\_ p.s.i.

Controlled by:  Valve  Cap  Plug

Temperature \_\_\_\_\_ °F. Quality \_\_\_\_\_

*Describe artesian or temperature zones below.*

**2. NATURE OF WORK**

New well  Deepened  Replacement

Well diameter increase

Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

**8. WELL TEST DATA**

Pump  Bailer  Air  Other \_\_\_\_\_

Discharge G.P.M.	Pumping Level	Hours Pumped
<u>50</u>		

**3. PROPOSED USE**

Domestic  Irrigation  Test  Municipal

Industrial  Stock  Waste Disposal or Injection

Other \_\_\_\_\_ (specify type)

**9. LITHOLOGIC LOG**

Bore Diam.	Depth		Material	Water	
	From	To		Yes	No
6"	0	56	Sand + Gravel		<input checked="" type="checkbox"/>
	56	59	Gravel + Brown clay	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
	59	85	Sand + Gravel	<input checked="" type="checkbox"/>	

**4. METHOD DRILLED**

Rotary  Air  Hydraulic  Reverse rotary

Cable  Dug  Other \_\_\_\_\_

**5. WELL CONSTRUCTION**

Casing schedule:  Steel  Concrete  Other \_\_\_\_\_

Thickness	Diameter	From	To
<u>.050</u> inches	<u>6"</u> inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used?  Yes  No

Was a packer or seal used?  Yes  No

Perforated?  Yes  No

How perforated?  Factory  Knife  Torch  Gun

Size of perforation \_\_\_\_\_ inches by \_\_\_\_\_ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed?  Yes  No

Manufacturer's name \_\_\_\_\_

Type \_\_\_\_\_ Model No. \_\_\_\_\_

Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Gravel packed?  Yes  No  Size of gravel \_\_\_\_\_

Placed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface seal depth 18' Material used in seal:  Cement grout

Bentonite  Puddling clay  \_\_\_\_\_

Sealing procedure used:  Slurry pit  Temp. surface casing

Overbore to seal depth

Method of joining casing:  Threaded  Welded  Solvent Weld


Cemented between strata

Describe access port \_\_\_\_\_

**10.** Work started 8/21/91 finished 8/21/91

**6. LOCATION OF WELL**

Sketch map location must agree with written location.



Subdivision Name \_\_\_\_\_

Lot No. \_\_\_\_\_ Block No. \_\_\_\_\_

County Teton

SE ¼ SW ¼ Sec. 3, T. 5 N  S  R. 45 E  W

**11. DRILLERS CERTIFICATION**

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Independent Drilling Firm No. 343

Address 664 W. 200 N. Bluff Date 8/26/91

Signed by (Firm Official) Brent Hendrick

and  
(Operator) Kip L. Rahmug

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT 093649

Use Typewriter or Ballpoint Pen

Permit ID 702847

1. DRILLING PERMIT NO. 22-96-E-0037-000


Other IDWR No. \_\_\_\_\_

2. OWNER:

Name Todd or Cindy Friend  
Address P.O. Box 590  
City Driggs State ID Zip 83422

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 5 North  or South   
Rge. 45 East  or West   
Sec. 3 SE 1/4 SW 1/4  
Gov't Lot \_\_\_\_\_ County Teton  
Lat: \_\_\_\_\_ Long: \_\_\_\_\_

Address of Well Site \_\_\_\_\_

(Give at least name of road + Distance to Road or Landmark)

Lt. \_\_\_\_\_ Bk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:

- Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)

- New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD

- Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>200</u>	<u>over Base</u>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_  
Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6 + 2</u>	<u>100</u>	<u>250</u>	<u>250</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

9. PERFORATIONS/SCREENS

- Perforations Method None  
 Screens Screen Type \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>
						<input type="checkbox"/>	<input type="checkbox"/>

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

64 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

11. WELL TESTS:

- Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>30</u>	<u>100</u>	<u>100</u>	<u>2 Hrs</u>

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
Water Quality test or comments: excellent  
Depth first Water Encountered 80'

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>6</u>	<u>0</u>	<u>14</u>	<u>Top Soil</u>		<input checked="" type="checkbox"/>
	<u>14</u>	<u>21</u>	<u>clay + gravel</u>		<input checked="" type="checkbox"/>
	<u>21</u>	<u>27</u>	<u>large Black Rock + clay</u>		<input checked="" type="checkbox"/>
	<u>27</u>	<u>40</u>	<u>hard gravel + clay</u>		<input checked="" type="checkbox"/>
	<u>40</u>	<u>55</u>	<u>small gravel + clay</u>		<input checked="" type="checkbox"/>
	<u>55</u>	<u>80</u>	<u>clay</u>	<input checked="" type="checkbox"/>	
<u>6</u>	<u>80</u>	<u>100</u>	<u>clay + small gravel</u>	<input checked="" type="checkbox"/>	

RECEIVED  
MAY 17 1996

Department of Water Resources  
Eastern District Office

AUG 21 1996

Completed Depth 100' (Measurable)  
Date Started 5-14-96 Completed 5-14-96

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Teton Water Works LP Firm No. 506

Firm Official [Signature] Date 5-15-96

Supervisor or Operator [Signature] Date 5-15-96

(Sign once if Firm Official & Operator)

**WELL DRILLER'S REPORT**

Permit ID 701985

55899

1. DRILLING PERMIT NO. 22-94-E-167  
Other IDWR No. \_\_\_\_\_

2. OWNER: Kent Hale  
Name \_\_\_\_\_  
Address P.O. Box 117  
City Tetonia State Id Zip 83452

3. LOCATION OF WELL by legal description:  
Sketch map location must agree with written location.

N		Twp. <u>5</u> North <input checked="" type="checkbox"/> or South <input type="checkbox"/>	
E		Rge. <u>15</u> East <input checked="" type="checkbox"/> or West <input type="checkbox"/>	
S		Sec. <u>3</u> SE 1/4 <input checked="" type="checkbox"/> SW 1/4 <input type="checkbox"/> NE 1/4 <input type="checkbox"/> NW 1/4 <input type="checkbox"/>	
W		Gov't Lot _____ County <u>TETON</u> 10 acres 40 acres 160 acres	

Address of Well Site 178 W. 400 N  
Pucksaddle Rd. City Tetonia  
(Give at least name of road + Distance to Road or Landmark)

Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. PROPOSED USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK  
 New Well  Modify or Repair  Replacement  Abandonment

6. DRILL METHOD  
 Mud Rotary  Air Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>3</u>	<u>Over bore</u>

Was drive shoe used? Y  N   
Was drive shoe seal tested? Y  N  How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6</u>	<u>0</u>	<u>60</u>	<u>250</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

9. PERFORATIONS/SCREENS NONE  
 Perforations Method \_\_\_\_\_  
 Screens Screen Type \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
15 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

11. WELL TESTS:

<input type="checkbox"/> Pump	<input type="checkbox"/> Bailer	<input checked="" type="checkbox"/> Air	<input type="checkbox"/> Flowing Artesian
Yield gal./min.	Drawdown	Pumping Level	Time
<u>35</u>	<u>55</u>	<u>85</u>	<u>1 Hr</u>

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
Water Quality test or comments: Clean + good

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>6</u>	<u>0</u>	<u>20</u>	<u>sand + gravel (12' H<sub>2</sub>O)</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>6</u>	<u>20</u>	<u>30</u>	<u>sand</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>6</u>	<u>30</u>	<u>40</u>	<u>washed gravel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>6</u>	<u>40</u>	<u>60</u>	<u>sand + gravel</u>	<input type="checkbox"/>	<input type="checkbox"/>

RECEIVED  
DEC 23 1994  
Department of Water Resources

RECEIVED  
DEC 14 1994  
Department of Water Resources  
Eastern District Office

RECEIVED  
OCT 14 1994  
Department of Water Resources  
Eastern District Office

MAY 08 1995

Completed Depth 60' (Measurable)  
Date: Started 9-18-94 Completed 9-18-94

13. DRILLER'S CERTIFICATION  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.  
Firm Name Teton Water Works Firm No. 506  
Firm Official \_\_\_\_\_ Date 10-12-94  
and  
Supervisor or Operator [Signature] Date \_\_\_\_\_  
(Sign once if Firm Official & Operator)





# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D 00751010

Drilling Permit No. \_\_\_\_\_

Water right or injection well # \_\_\_\_\_

2. OWNER: Darren Enrico

Name \_\_\_\_\_

Address 548 Cobblecrest Rd.

City Driggs State ID Zip 83422

3. WELL LOCATION:

Twp. 5 North  or South  Rge. 46 East  or West

Sec. 3 \_\_\_\_\_ 1/4 SW 1/4 SE 1/4 \_\_\_\_\_

Gov't Lot \_\_\_\_\_ County Teton

Lat. 43 ° 47.023 (Deg. and Decimal minutes)

Long. 111 ° 7.610 (Deg. and Decimal minutes)

Address of Well Site 4183 Los Pinos Dr.

City Teton

(Give at least name of road + Distance to Road or Landmark)

Lot. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection

Other \_\_\_\_\_

5. TYPE OF WORK:

New well  Replacement well  Modify existing well

Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
<u>Bentonite</u>	<u>0</u>	<u>41'</u>	<u>20 Bags</u>	<u>over bore</u>

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
<u>6"</u>	<u>+2</u>	<u>98'</u>	<u>.230"</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_

9. PERFORATIONS/SCREENS:

Perforations  Y  N Method \_\_\_\_\_

Manufactured screen  Y  N Type \_\_\_\_\_

Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

11. FLOWING ARTESIAN:

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_

Describe control device \_\_\_\_\_

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 30' Static water level (ft) 30'

Water temp. (°F) \_\_\_\_\_ Bottom hole temp. (°F) \_\_\_\_\_

Describe access port \_\_\_\_\_

Well test:			Test method:			
Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
<u>6"</u>	<u>0</u>	<u>40'</u>	<u>Clay Gravel</u>		<u>K</u>
<u>6"</u>	<u>40</u>	<u>65'</u>	<u>Clay Gravel</u>	<u>K</u>	
<u>6"</u>	<u>65'</u>	<u>68'</u>	<u>Clay</u>		<u>K</u>
<u>6"</u>	<u>68</u>	<u>100'</u>	<u>Clay &amp; Gravel</u>	<u>K</u>	

RECEIVED  
AUG 13 2018  
Department of Water Resources  
Eastern Region

Completed Depth (Measurable): 98'

Date Started: 5-30-18 Date Completed: 5-31-18

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Denning Drilling Co. No. 518

\*Principal Driller Daniel Denning Date 6-12-18

\*Driller Daniel Denning Date 6-12-18

\*Operator II \_\_\_\_\_ Date \_\_\_\_\_

Operator I Phil Cook Date 6/12/18

\* Signature of Principal Driller and rig operator are required.

Form 2387  
6/02  
DMD

IDAHO DEPARTMENT OF WATER RESOURCES  
WELL DRILLER'S REPORT

22

Office Use Only			
Well ID No.	_____		
Inspected by	_____		
Twp	Rge	Sec	
_____	_____	_____	_____
Lat: _____	: _____	Long: _____	: _____

1. WELL TAG NO. D 0037951  
DRILLING PERMIT NO. \_\_\_\_\_  
Water Right or Injection Well No. \_\_\_\_\_

2. OWNER:  
Name Brad R. Nelson  
Address P.O. Box 187  
City Leticia State Id Zip 83452

3. LOCATION OF WELL by legal description:  
You must provide address or Lot, Blk, Sub. or Directions to well.  
Twp. 5 North  or South   
Rge. 45 East  or West   
Sec. 3 1/4 SW 1/4 SE 1/4  
Gov'l Lot \_\_\_\_\_  
County Leticia 10 acres 40 acres 160 acres  
Lat: \_\_\_\_\_ Long: \_\_\_\_\_  
Address of Well Site Loc 1 Lospinos Sub P.U.  
City \_\_\_\_\_  
Lt. 1 Blk. \_\_\_\_\_ Sub. Name Lospinos

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>450</u>	<u>COUMBORE</u>

Was drive shoe used?  Y  N Shoe Depth(s) 99'  
Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6</u>	<u>+1</u>	<u>99</u>	<u>252</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
Packer  Y  N Type \_\_\_\_\_

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method \_\_\_\_\_  
Screen Type & Method of Installation \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
46 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

12. WELL TESTS:  
 Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>207</u>	<u>450 @ 250</u>	<u>762</u>	

Water Temp. 100 Bottom hole temp 100  
Water Quality test or comments: \_\_\_\_\_  
Depth first Water Encounter 66'

13. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8</u>	<u>0</u>	<u>20</u>	<u>Sand &amp; gravel</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>6</u>	<u>20</u>	<u>70</u>	<u>CLAY &amp; GRAVEL</u>	<input type="checkbox"/>	<input type="checkbox"/>
<u>1</u>	<u>70</u>	<u>80</u>	<u>BROWN CLAY</u>	<input type="checkbox"/>	<input type="checkbox"/>
<u>1</u>	<u>80</u>	<u>100</u>	<u>CLAY &amp; GRAVEL</u>	<input type="checkbox"/>	<input type="checkbox"/>

RECEIVED

JAN 26 2006

Department of Water Resources  
Eastern Region

Completed Depth 100' (Measurable)  
Date: Started 1-19-06 Completed 1-24-06

14. DRILLER'S CERTIFICATION  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.  
Company Name MARK MACHILL WELDR Firm No. 612  
Principal Driller [Signature] Date 1-24-06  
and  
Driller or Operator II \_\_\_\_\_ Date \_\_\_\_\_  
Operator I \_\_\_\_\_ Date \_\_\_\_\_

Principal Driller and Rig Operator Required.  
Operator I must have signature of Driller/Operator II.



USE TYPEWRITER OR BALL POINT PEN

State of Idaho  
Department of Water Resources

WELL DRILLER'S REPORT

RECEIVED  
JUN 30 1977

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.  
Permit ID 822910

1. WELL OWNER  
Name Floyd Baler  
Address Rt. #1 Tetonia, Idaho 83452  
Owner's Permit No. \_\_\_\_\_

7. WATER LEVEL  
Department of Water Resources  
Eastern District Office  
Static water level 23 feet below land surface  
Flowing?  Yes  No G.P.M. flow \_\_\_\_\_  
Temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_  
Artesian closed-in pressure \_\_\_\_\_ p.s.i.  
Controlled by  Valve  Cap  Plug

2. NATURE OF WORK  
 New well  Deepened  Replacement  
 Abandoned (describe method of abandoning)

8. WELL TEST DATA  
 Pump  Bailer  Other  
Discharge G.P.M. Draw Down Hours Pumped

3. PROPOSED USE  
 Domestic  Irrigation  Test  Other (specify type)  
 Municipal  Industrial  Stock  Waste Disposal or Injection

9. LITHOLOGIC LOG 46363

4. METHOD DRILLED  
 Cable  Rotary  Dug  Other

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
6"	0'	6'	Clay and cobble rocks		X
	6'	23'	Clay and gravel		X
	23'	60'	Clay gravel and intermixed cobble rock		X

5. WELL CONSTRUCTION  
Diameter of hole 6 inches Total depth 60 feet  
Casing schedule:  Steel  Concrete  
Thickness Diameter From To  
.250 inches 6 inches + 1 feet 60 feet  
\_\_\_\_\_ inches \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
\_\_\_\_\_ inches \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
\_\_\_\_\_ inches \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
Was casing drive shoe used?  Yes  No  
Was a packer or seal used?  Yes  No  
Perforated?  Yes  No  
How perforated?  Factory  Knife  Torch  
Size of perforation \_\_\_\_\_ inches by \_\_\_\_\_ inches  
Number From To  
\_\_\_\_\_ perforations \_\_\_\_\_ feet \_\_\_\_\_ feet  
\_\_\_\_\_ perforations \_\_\_\_\_ feet \_\_\_\_\_ feet  
\_\_\_\_\_ perforations \_\_\_\_\_ feet \_\_\_\_\_ feet  
Well screen installed?  Yes  No  
Manufacturer's name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Diameter \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Gravel packed?  Yes  No Size of gravel \_\_\_\_\_  
Placed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface seal depth 21' Material used in seal  Cement grout  
 Pudding clay  Well cuttings  
Sealing procedure used  Slurry pit  Temporary surface casing  
 Overbore to seal depth

6. LOCATION OF WELL  
Sketch map location must agree with written location.  
Subdivision Name \_\_\_\_\_  
Lot No. \_\_\_\_\_ Block No. \_\_\_\_\_  
County Teton  
SW ¼ SW ¼ Sec. 3, T. 5 N. R. 45 E/W

10. Work started March 15, 1977 finished March 15, 1977

11. DRILLERS CERTIFICATION  
Firm Name D. Denning Well Drilling Firm No. 10  
Address Box 64 Ucon, Idaho 83454 Date March 18 '77  
Signed by (Firm Official) [Signature]  
and  
(Operator) Daniel Denning



IDAHO DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

22

Office Use Only			
Well ID No.	_____		
Inspected by	_____		
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat: : :	Long: : :		

1. WELL TAG NO. D 0048827  
 DRILLING PERMIT NO. \_\_\_\_\_  
 Water Right or Injection Well No. \_\_\_\_\_

2. OWNER:  
 Name Shawn Perkins  
 Address 307 North Hwy 33  
 City Driggs State ID Zip 83455

3. LOCATION OF WELL by legal description:  
 You must provide address or Lot, Blk, Sub. or Directions to well.  
 Twp. 5 North  or South   
 Rge. 45 East  or West   
 Sec. 10 1/4 NW 1/4 NE 1/4  
 Gov't Lot \_\_\_\_\_ County Teton  
 Lat: 43:46:869 Long: 111:07:899  
 Address of Well Site 400 N. 95 West  
 City Driggs  
(Give at least name of road + Distance to Road or Landmark)  
 Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>benzite</u>	<u>0'</u>	<u>18'</u>	<u>450 lbs</u>	<u>overbore</u>

Was drive shoe used?  Y  N Shoe Depth(s) 100'  
 Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6"</u>	<u>0'</u>	<u>100'</u>	<u>290</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
 Packer  Y  N Type \_\_\_\_\_

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method \_\_\_\_\_  
 Screen Type & Method of Installation \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
20 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
 Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

12. WELL TESTS:  
 Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
 Water Quality test or comments: \_\_\_\_\_  
 Depth first Water Encounter \_\_\_\_\_

13. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8"</u>	<u>0'</u>	<u>18'</u>	<u>clay-gravels</u>		<input checked="" type="checkbox"/>
<u>6"</u>	<u>18'</u>	<u>45'</u>	<u>clay-gravels</u>	<input checked="" type="checkbox"/>	
<u>6"</u>	<u>45'</u>	<u>60'</u>	<u>clay-sand-gravels</u>	<input checked="" type="checkbox"/>	
<u>6"</u>	<u>60'</u>	<u>80'</u>	<u>clay-sand-gravels</u>	<input checked="" type="checkbox"/>	
<u>6"</u>	<u>80'</u>	<u>100'</u>	<u>clay-gravels</u>	<input checked="" type="checkbox"/>	

RECEIVED  
 OCT 11 2007  
 Department of Water Resources  
 Eastern Region

Completed Depth 100' (Measurable)  
 Date: Started 10-2-07 Completed 10-2-07

14. DRILLER'S CERTIFICATION  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Deming Drilling Firm No. 518  
 Principal Driller Deming Date 10-3-07  
 and Driller or Operator II Deming Date 10-3-07  
 Operator I John Deming Date 10-5-07  
 Principal Driller and Rig Operator Required.  
 Operator I must have signature of Driller/Operator II.

IDAHO DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

22

Office Use Only			
Well ID No.	_____		
Inspected by	_____		
Twp _____	Rge _____	Sec _____	
_____ 1/4		_____ 1/4	_____ 1/4
Lat: _____	: _____	Long: _____	: _____

1. WELL TAG NO. D 0035757  
 DRILLING PERMIT NO. \_\_\_\_\_  
 Water Right or Injection Well No. \_\_\_\_\_

2. OWNER:  
 Name Highland Meadows LLC  
 Address PO BOX 408  
 City Driggs State ID Zip 83422

3. LOCATION OF WELL by legal description:  
 You must provide address or Lot, Blk, Sub. or Directions to well.  
 Twp. 5N North  or South   
 Rge. 45E East  or West   
 Sec. 10 1/4 SW 1/4 SW 1/4  
 Gov't Lot \_\_\_\_\_ To acres \_\_\_\_\_ County Teton  
 Lat: \_\_\_\_\_ Long: \_\_\_\_\_  
 Address of Well Site \_\_\_\_\_

(Give at least name of road + Distance to Road or Landmark)  
 Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name Highland Meadows Subdivision

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other Subdivision - Domestic

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
NEAT Cement	0'	60'	3 1/2 yds	over Bore

Was drive shoe used?  Y  N Shoe Depth(s) 140'  
 Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
16"	#1	60'	.50	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12"	#1	116'	.322	Steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
 Packer  Y  N Type \_\_\_\_\_

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method Johanson Wirewrap (Stainless)  
 Screen Type & Method of Installation Forward w/ Packer

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
116'	140'	.080"	Tele	12"	Stainless	<input type="checkbox"/>	<input type="checkbox"/>

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
35' ft. below ground Artesian pressure \_\_\_\_\_ lb.  
 Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

12. WELL TESTS:  
 Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
 Water Quality test or comments: \_\_\_\_\_  
 Depth first Water Encounter 40'

13. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
16"	0'	20'	Gravels, Sand		<input checked="" type="checkbox"/>
16"	20'	40'	Gravels, Sand	<input checked="" type="checkbox"/>	
16"	40'	50'	13clones, Gravel	<input checked="" type="checkbox"/>	
16"	50'	60'	Gravels (Small)	<input checked="" type="checkbox"/>	
12"	60'	80'	Gravels (Small)	<input checked="" type="checkbox"/>	
12"	80'	100'	Gravels (Small)	<input checked="" type="checkbox"/>	
12"	100'	120'	Gravel (Large)	<input checked="" type="checkbox"/>	
12"	120'	140'	Gravel (mixed)	<input checked="" type="checkbox"/>	

RECEIVED  
 MAY 06 2005

Department of Water Resources  
 Eastern Region

Completed Depth 140' (Measurable)  
 Date: Started 11-26-04 Completed 4-28-05

14. DRILLER'S CERTIFICATION  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.  
 Company Name Denning Well Drilling Firm No. 518  
 Principal Driller Denning Date 4-28-05  
 and Driller or Operator II \_\_\_\_\_ Date \_\_\_\_\_  
 Operator I Denning Date 2/17/05  
 Principal Driller and Rig Operator Required.  
 Operator I must have signature of Driller/Operator II.







IDAHO DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Office Use Only

Well ID No. \_\_\_\_\_  
 Inspected by \_\_\_\_\_  
 Twp \_\_\_\_\_ Rge \_\_\_\_\_ Sec \_\_\_\_\_  
 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4  
 Lat: : : Long: : :

22

1. **WELL TAG NO. D** 0044152  
 DRILLING PERMIT NO. \_\_\_\_\_  
 Water Right or Injection Well No. \_\_\_\_\_

2. **OWNER:**  
 Name Arnon Myler  
 Address PO Box 269  
 City Driggs State Id Zip 83420

3. **LOCATION OF WELL by legal description:**  
 You must provide address or Lot, Blk, Sub. or Directions to well.  
 Twp. 5 North  or South   
 Rge. 45 East  or West   
 Sec. 11 1/4 SE 1/4 NW 1/4  
 Gov't Lot \_\_\_\_\_  
 County terran  
 Lat: : : Long: : :  
 Address of Well Site 362 N Hwy 33  
 City Driggs  
(Give at least name of road + Distance to Road or Landmark)  
 Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. **USE:**  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. **TYPE OF WORK** check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. **DRILL METHOD:**  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. **SEALING PROCEDURES**

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>bentonite</u>	<u>0</u>	<u>20</u>	<u>160</u>	<u>overbore</u>

Was drive shoe used?  Y  N Shoe Depth(s) 100  
 Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. **CASING/LINER:**

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6</u>	<u>+2</u>	<u>100</u>	<u>250</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
 Packer  Y  N Type \_\_\_\_\_

9. **PERFORATIONS/SCREENS PACKER TYPE**  
 Perforation Method \_\_\_\_\_  
 Screen Type & Method of Installation \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. **FILTER PACK**

Filter Material	From	To	Weight / Volume	Placement Method

11. **STATIC WATER LEVEL OR ARTESIAN PRESSURE:**  
56 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
 Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: well cap

12. **WELL TESTS:**  
 Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>30</u>			

Water Temp. 51 Bottom hole temp. \_\_\_\_\_  
 Water Quality test or comments: \_\_\_\_\_

13. **LITHOLOGIC LOG: (Describe repairs or abandonment)**

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8</u>	<u>0</u>	<u>20</u>	<u>gravel sand clay</u>		<input checked="" type="checkbox"/>
<u>6</u>	<u>20</u>	<u>56</u>	<u>gravel clay sand</u>		<input checked="" type="checkbox"/>
<u>6</u>	<u>56</u>	<u>60</u>	<u>gravel</u>	<input checked="" type="checkbox"/>	
<u>6</u>	<u>60</u>	<u>90</u>	<u>sand clay gravel</u>	<input checked="" type="checkbox"/>	
<u>6</u>	<u>90</u>	<u>100</u>	<u>gravel</u>	<input checked="" type="checkbox"/>	

RECEIVED  
SEP 25 2006  
Department of Water Resources  
Eastern Region

Completed Depth 100 (Measurable)  
 Date: Started 7-18-06 Completed 7-18-06

14. **DRILLER'S CERTIFICATION**  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name High Plains Firm No. 299  
 Principal Driller Marion Franher Date 7-21-06  
 and  
 Driller or Operator II \_\_\_\_\_ Date \_\_\_\_\_  
 Operator I Travis Franher Date 7-21-06  
 Principal Driller and Rig Operator Required.  
 Operator I must have signature of Driller/Operator II.

# Appendix C: SOIL RESOURCES



United States  
Department of  
Agriculture

**NRCS**

Natural  
Resources  
Conservation  
Service

A product of the National  
Cooperative Soil Survey,  
a joint effort of the United  
States Department of  
Agriculture and other  
Federal agencies, State  
agencies including the  
Agricultural Experiment  
Stations, and local  
participants

# Custom Soil Resource Report for Teton Area, Idaho and Wyoming

## JC Ranches Subdivision



# Preface

---

Soil surveys contain information that affects land use planning in survey areas. They highlight soil limitations that affect various land uses and provide information about the properties of the soils in the survey areas. Soil surveys are designed for many different users, including farmers, ranchers, foresters, agronomists, urban planners, community officials, engineers, developers, builders, and home buyers. Also, conservationists, teachers, students, and specialists in recreation, waste disposal, and pollution control can use the surveys to help them understand, protect, or enhance the environment.

Various land use regulations of Federal, State, and local governments may impose special restrictions on land use or land treatment. Soil surveys identify soil properties that are used in making various land use or land treatment decisions. The information is intended to help the land users identify and reduce the effects of soil limitations on various land uses. The landowner or user is responsible for identifying and complying with existing laws and regulations.

Although soil survey information can be used for general farm, local, and wider area planning, onsite investigation is needed to supplement this information in some cases. Examples include soil quality assessments (<http://www.nrcs.usda.gov/wps/portal/nrcs/main/soils/health/>) and certain conservation and engineering applications. For more detailed information, contact your local USDA Service Center (<https://offices.sc.egov.usda.gov/locator/app?agency=nrcs>) or your NRCS State Soil Scientist ([http://www.nrcs.usda.gov/wps/portal/nrcs/detail/soils/contactus/?cid=nrcs142p2\\_053951](http://www.nrcs.usda.gov/wps/portal/nrcs/detail/soils/contactus/?cid=nrcs142p2_053951)).

Great differences in soil properties can occur within short distances. Some soils are seasonally wet or subject to flooding. Some are too unstable to be used as a foundation for buildings or roads. Clayey or wet soils are poorly suited to use as septic tank absorption fields. A high water table makes a soil poorly suited to basements or underground installations.

The National Cooperative Soil Survey is a joint effort of the United States Department of Agriculture and other Federal agencies, State agencies including the Agricultural Experiment Stations, and local agencies. The Natural Resources Conservation Service (NRCS) has leadership for the Federal part of the National Cooperative Soil Survey.

Information about soils is updated periodically. Updated information is available through the NRCS Web Soil Survey, the site for official soil survey information.

The U.S. Department of Agriculture (USDA) prohibits discrimination in all its programs and activities on the basis of race, color, national origin, age, disability, and where applicable, sex, marital status, familial status, parental status, religion, sexual orientation, genetic information, political beliefs, reprisal, or because all or a part of an individual's income is derived from any public assistance program. (Not all prohibited bases apply to all programs.) Persons with disabilities who require

alternative means for communication of program information (Braille, large print, audiotape, etc.) should contact USDA's TARGET Center at (202) 720-2600 (voice and TDD). To file a complaint of discrimination, write to USDA, Director, Office of Civil Rights, 1400 Independence Avenue, S.W., Washington, D.C. 20250-9410 or call (800) 795-3272 (voice) or (202) 720-6382 (TDD). USDA is an equal opportunity provider and employer.

# Contents

---

<b>Preface</b> .....	2
<b>How Soil Surveys Are Made</b> .....	5
<b>Soil Map</b> .....	8
Soil Map.....	9
Legend.....	10
Map Unit Legend.....	11
Map Unit Descriptions.....	11
Teton Area, Idaho and Wyoming.....	13
13101—Redfish-Foxcreek complex, 0 to 2 percent slopes.....	13
13113—Foxcreek mucky peat, 0 to 2 percent slopes.....	14
13429—Alpine gravelly loam, 0 to 2 percent slopes.....	16
13430—Alpine-St. Anthony complex, 0 to 2 percent slopes.....	17
13431—Feltonia-Arimo complex, 0 to 2 percent slopes.....	19
<b>References</b> .....	22

# How Soil Surveys Are Made

---

Soil surveys are made to provide information about the soils and miscellaneous areas in a specific area. They include a description of the soils and miscellaneous areas and their location on the landscape and tables that show soil properties and limitations affecting various uses. Soil scientists observed the steepness, length, and shape of the slopes; the general pattern of drainage; the kinds of crops and native plants; and the kinds of bedrock. They observed and described many soil profiles. A soil profile is the sequence of natural layers, or horizons, in a soil. The profile extends from the surface down into the unconsolidated material in which the soil formed or from the surface down to bedrock. The unconsolidated material is devoid of roots and other living organisms and has not been changed by other biological activity.

Currently, soils are mapped according to the boundaries of major land resource areas (MLRAs). MLRAs are geographically associated land resource units that share common characteristics related to physiography, geology, climate, water resources, soils, biological resources, and land uses (USDA, 2006). Soil survey areas typically consist of parts of one or more MLRA.

The soils and miscellaneous areas in a survey area occur in an orderly pattern that is related to the geology, landforms, relief, climate, and natural vegetation of the area. Each kind of soil and miscellaneous area is associated with a particular kind of landform or with a segment of the landform. By observing the soils and miscellaneous areas in the survey area and relating their position to specific segments of the landform, a soil scientist develops a concept, or model, of how they were formed. Thus, during mapping, this model enables the soil scientist to predict with a considerable degree of accuracy the kind of soil or miscellaneous area at a specific location on the landscape.

Commonly, individual soils on the landscape merge into one another as their characteristics gradually change. To construct an accurate soil map, however, soil scientists must determine the boundaries between the soils. They can observe only a limited number of soil profiles. Nevertheless, these observations, supplemented by an understanding of the soil-vegetation-landscape relationship, are sufficient to verify predictions of the kinds of soil in an area and to determine the boundaries.

Soil scientists recorded the characteristics of the soil profiles that they studied. They noted soil color, texture, size and shape of soil aggregates, kind and amount of rock fragments, distribution of plant roots, reaction, and other features that enable them to identify soils. After describing the soils in the survey area and determining their properties, the soil scientists assigned the soils to taxonomic classes (units). Taxonomic classes are concepts. Each taxonomic class has a set of soil characteristics with precisely defined limits. The classes are used as a basis for comparison to classify soils systematically. Soil taxonomy, the system of taxonomic classification used in the United States, is based mainly on the kind and character of soil properties and the arrangement of horizons within the profile. After the soil



## Custom Soil Resource Report

scientists classified and named the soils in the survey area, they compared the individual soils with similar soils in the same taxonomic class in other areas so that they could confirm data and assemble additional data based on experience and research.

The objective of soil mapping is not to delineate pure map unit components; the objective is to separate the landscape into landforms or landform segments that have similar use and management requirements. Each map unit is defined by a unique combination of soil components and/or miscellaneous areas in predictable proportions. Some components may be highly contrasting to the other components of the map unit. The presence of minor components in a map unit in no way diminishes the usefulness or accuracy of the data. The delineation of such landforms and landform segments on the map provides sufficient information for the development of resource plans. If intensive use of small areas is planned, onsite investigation is needed to define and locate the soils and miscellaneous areas.

Soil scientists make many field observations in the process of producing a soil map. The frequency of observation is dependent upon several factors, including scale of mapping, intensity of mapping, design of map units, complexity of the landscape, and experience of the soil scientist. Observations are made to test and refine the soil-landscape model and predictions and to verify the classification of the soils at specific locations. Once the soil-landscape model is refined, a significantly smaller number of measurements of individual soil properties are made and recorded. These measurements may include field measurements, such as those for color, depth to bedrock, and texture, and laboratory measurements, such as those for content of sand, silt, clay, salt, and other components. Properties of each soil typically vary from one point to another across the landscape.

Observations for map unit components are aggregated to develop ranges of characteristics for the components. The aggregated values are presented. Direct measurements do not exist for every property presented for every map unit component. Values for some properties are estimated from combinations of other properties.

While a soil survey is in progress, samples of some of the soils in the area generally are collected for laboratory analyses and for engineering tests. Soil scientists interpret the data from these analyses and tests as well as the field-observed characteristics and the soil properties to determine the expected behavior of the soils under different uses. Interpretations for all of the soils are field tested through observation of the soils in different uses and under different levels of management. Some interpretations are modified to fit local conditions, and some new interpretations are developed to meet local needs. Data are assembled from other sources, such as research information, production records, and field experience of specialists. For example, data on crop yields under defined levels of management are assembled from farm records and from field or plot experiments on the same kinds of soil.

Predictions about soil behavior are based not only on soil properties but also on such variables as climate and biological activity. Soil conditions are predictable over long periods of time, but they are not predictable from year to year. For example, soil scientists can predict with a fairly high degree of accuracy that a given soil will have a high water table within certain depths in most years, but they cannot predict that a high water table will always be at a specific level in the soil on a specific date.

After soil scientists located and identified the significant natural bodies of soil in the survey area, they drew the boundaries of these bodies on aerial photographs and

## Custom Soil Resource Report


identified each as a specific map unit. Aerial photographs show trees, buildings, fields, roads, and rivers, all of which help in locating boundaries accurately.

# Soil Map


---

The soil map section includes the soil map for the defined area of interest, a list of soil map units on the map and extent of each map unit, and cartographic symbols displayed on the map. Also presented are various metadata about data used to produce the map, and a description of each soil map unit.

# Custom Soil Resource Report Soil Map



Soil Map may not be valid at this scale.



### MAP LEGEND

- Area of Interest (AOI)**
  - Area of Interest (AOI)
- Soils**
  - Soil Map Unit Polygons
  - Soil Map Unit Lines
  - Soil Map Unit Points
- Special Point Features**
  - Blowout
  - Borrow Pit
  - Clay Spot
  - Closed Depression
  - Gravel Pit
  - Gravelly Spot
  - Landfill
  - Lava Flow
  - Marsh or swamp
  - Mine or Quarry
  - Miscellaneous Water
  - Perennial Water
  - Rock Outcrop
  - Saline Spot
  - Sandy Spot
  - Severely Eroded Spot
  - Sinkhole
  - Slide or Slip
  - Sodic Spot
- Water Features**
  - Streams and Canals
- Transportation**
  - Rails
  - Interstate Highways
  - US Routes
  - Major Roads
  - Local Roads
- Background**
  - Aerial Photography
- Other Features**
  - Spoil Area
  - Stony Spot
  - Very Stony Spot
  - Wet Spot
  - Other
  - Special Line Features

### MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:24,000.

Warning: Soil Map may not be valid at this scale.

Enlargement of maps beyond the scale of mapping can cause misunderstanding of the detail of mapping and accuracy of soil line placement. The maps do not show the small areas of contrasting soils that could have been shown at a more detailed scale.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service  
 Web Soil Survey URL:  
 Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: Teton Area, Idaho and Wyoming  
 Survey Area Data: Version 10, Sep 9, 2021

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Sep 24, 2011—Oct 25, 2016

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

## Map Unit Legend

Map Unit Symbol	Map Unit Name	Acres in AOI	Percent of AOI
13101	Redfish-Foxcreek complex, 0 to 2 percent slopes	22.9	15.1%
13113	Foxcreek mucky peat, 0 to 2 percent slopes	15.0	9.9%
13429	Alpine gravelly loam, 0 to 2 percent slopes	7.5	4.9%
13430	Alpine-St. Anthony complex, 0 to 2 percent slopes	65.5	43.2%
13431	Feltonia-Arimo complex, 0 to 2 percent slopes	40.8	26.9%
<b>Totals for Area of Interest</b>		<b>151.6</b>	<b>100.0%</b>

## Map Unit Descriptions

The map units delineated on the detailed soil maps in a soil survey represent the soils or miscellaneous areas in the survey area. The map unit descriptions, along with the maps, can be used to determine the composition and properties of a unit.

A map unit delineation on a soil map represents an area dominated by one or more major kinds of soil or miscellaneous areas. A map unit is identified and named according to the taxonomic classification of the dominant soils. Within a taxonomic class there are precisely defined limits for the properties of the soils. On the landscape, however, the soils are natural phenomena, and they have the characteristic variability of all natural phenomena. Thus, the range of some observed properties may extend beyond the limits defined for a taxonomic class. Areas of soils of a single taxonomic class rarely, if ever, can be mapped without including areas of other taxonomic classes. Consequently, every map unit is made up of the soils or miscellaneous areas for which it is named and some minor components that belong to taxonomic classes other than those of the major soils.

Most minor soils have properties similar to those of the dominant soil or soils in the map unit, and thus they do not affect use and management. These are called noncontrasting, or similar, components. They may or may not be mentioned in a particular map unit description. Other minor components, however, have properties and behavioral characteristics divergent enough to affect use or to require different management. These are called contrasting, or dissimilar, components. They generally are in small areas and could not be mapped separately because of the scale used. Some small areas of strongly contrasting soils or miscellaneous areas are identified by a special symbol on the maps. If included in the database for a given area, the contrasting minor components are identified in the map unit descriptions along with some characteristics of each. A few areas of minor components may not have been observed, and consequently they are not mentioned in the descriptions, especially where the pattern was so complex that it was impractical to make enough observations to identify all the soils and miscellaneous areas on the landscape.

## Custom Soil Resource Report

The presence of minor components in a map unit in no way diminishes the usefulness or accuracy of the data. The objective of mapping is not to delineate pure taxonomic classes but rather to separate the landscape into landforms or landform segments that have similar use and management requirements. The delineation of such segments on the map provides sufficient information for the development of resource plans. If intensive use of small areas is planned, however, onsite investigation is needed to define and locate the soils and miscellaneous areas.

An identifying symbol precedes the map unit name in the map unit descriptions. Each description includes general facts about the unit and gives important soil properties and qualities.

Soils that have profiles that are almost alike make up a *soil series*. Except for differences in texture of the surface layer, all the soils of a series have major horizons that are similar in composition, thickness, and arrangement.

Soils of one series can differ in texture of the surface layer, slope, stoniness, salinity, degree of erosion, and other characteristics that affect their use. On the basis of such differences, a soil series is divided into *soil phases*. Most of the areas shown on the detailed soil maps are phases of soil series. The name of a soil phase commonly indicates a feature that affects use or management. For example, Alpha silt loam, 0 to 2 percent slopes, is a phase of the Alpha series.

Some map units are made up of two or more major soils or miscellaneous areas. These map units are complexes, associations, or undifferentiated groups.

A *complex* consists of two or more soils or miscellaneous areas in such an intricate pattern or in such small areas that they cannot be shown separately on the maps. The pattern and proportion of the soils or miscellaneous areas are somewhat similar in all areas. Alpha-Beta complex, 0 to 6 percent slopes, is an example.

An *association* is made up of two or more geographically associated soils or miscellaneous areas that are shown as one unit on the maps. Because of present or anticipated uses of the map units in the survey area, it was not considered practical or necessary to map the soils or miscellaneous areas separately. The pattern and relative proportion of the soils or miscellaneous areas are somewhat similar. Alpha-Beta association, 0 to 2 percent slopes, is an example.

An *undifferentiated group* is made up of two or more soils or miscellaneous areas that could be mapped individually but are mapped as one unit because similar interpretations can be made for use and management. The pattern and proportion of the soils or miscellaneous areas in a mapped area are not uniform. An area can be made up of only one of the major soils or miscellaneous areas, or it can be made up of all of them. Alpha and Beta soils, 0 to 2 percent slopes, is an example.

Some surveys include *miscellaneous areas*. Such areas have little or no soil material and support little or no vegetation. Rock outcrop is an example.

## Teton Area, Idaho and Wyoming

### 13101—Redfish-Foxcreek complex, 0 to 2 percent slopes

#### Map Unit Setting

*National map unit symbol:* 1qmkh  
*Elevation:* 5,920 to 6,230 feet  
*Mean annual precipitation:* 16 to 18 inches  
*Mean annual air temperature:* 38 to 44 degrees F  
*Frost-free period:* 20 to 50 days  
*Farmland classification:* Not prime farmland

#### Map Unit Composition

*Redfish and similar soils:* 70 percent  
*Foxcreek and similar soils:* 30 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

#### Description of Redfish

##### Setting

*Landform:* Flood plains, fan remnants  
*Down-slope shape:* Linear  
*Across-slope shape:* Linear  
*Parent material:* Mixed alluvium

##### Typical profile

*Oe - 0 to 2 inches:* mucky peat  
*A - 2 to 10 inches:* loam  
*AB - 10 to 13 inches:* gravelly loam  
*2BC - 13 to 16 inches:* very gravelly loamy sand  
*2C - 16 to 43 inches:* extremely gravelly sand  
*2Cg - 43 to 60 inches:* extremely gravelly coarse sand

##### Properties and qualities

*Slope:* 0 to 2 percent  
*Depth to restrictive feature:* More than 80 inches  
*Drainage class:* Poorly drained  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately high to high  
(0.57 to 1.98 in/hr)  
*Depth to water table:* About 0 to 10 inches  
*Frequency of flooding:* OccasionalNone  
*Frequency of ponding:* None  
*Calcium carbonate, maximum content:* 4 percent  
*Maximum salinity:* Nonsaline to very slightly saline (0.0 to 2.0 mmhos/cm)  
*Sodium adsorption ratio, maximum:* 1.0  
*Available water supply, 0 to 60 inches:* Low (about 3.2 inches)

##### Interpretive groups

*Land capability classification (irrigated):* 6c  
*Land capability classification (nonirrigated):* 6c  
*Hydrologic Soil Group:* C/D  
*Ecological site:* R013XY050ID - RIPARIAN WET MEADOW SALIX/CAREX  
*Hydric soil rating:* Yes



## Description of Foxcreek

### Setting

*Landform:* Drainageways, flood plains  
*Down-slope shape:* Linear  
*Across-slope shape:* Concave, linear  
*Parent material:* Mixed alluvium

### Typical profile

*Oe - 0 to 2 inches:* mucky peat  
*Ag - 2 to 8 inches:* loam  
*ABg - 8 to 15 inches:* loam  
*Bg1 - 15 to 21 inches:* loam  
*2Bg2 - 21 to 26 inches:* very gravelly coarse sandy loam  
*2Bkg - 26 to 42 inches:* very gravelly loamy sand  
*2Cg - 42 to 60 inches:* extremely gravelly coarse sand

### Properties and qualities

*Slope:* 0 to 2 percent  
*Depth to restrictive feature:* More than 80 inches  
*Drainage class:* Poorly drained  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to moderately high (0.01 to 0.57 in/hr)  
*Depth to water table:* About 0 to 10 inches  
*Frequency of flooding:* OccasionalNone  
*Frequency of ponding:* None  
*Calcium carbonate, maximum content:* 15 percent  
*Maximum salinity:* Nonsaline to very slightly saline (0.0 to 2.0 mmhos/cm)  
*Sodium adsorption ratio, maximum:* 1.0  
*Available water supply, 0 to 60 inches:* Low (about 5.2 inches)

### Interpretive groups

*Land capability classification (irrigated):* 6c  
*Land capability classification (nonirrigated):* 6c  
*Hydrologic Soil Group:* C/D  
*Ecological site:* R013XY050ID - RIPARIAN WET MEADOW SALIX/CAREX  
*Hydric soil rating:* Yes

## 13113—Foxcreek mucky peat, 0 to 2 percent slopes

### Map Unit Setting

*National map unit symbol:* 1qmks  
*Elevation:* 5,920 to 6,520 feet  
*Mean annual precipitation:* 16 to 18 inches  
*Mean annual air temperature:* 38 to 44 degrees F  
*Frost-free period:* 20 to 50 days  
*Farmland classification:* Not prime farmland


### Map Unit Composition

*Foxcreek and similar soils:* 90 percent


# GEOLOGIC MAP OF THE CLAWSON QUADRANGLE, TETON COUNTY, IDAHO AND TETON COUNTY, WYOMING

Glenn F. Embree<sup>1</sup>

2014



## CORRELATION OF MAP UNITS



## SYMBOLS

- Contact: dashed where approximately located.
- Normal fault: ball and bar on downthrown side; dashed where approximately located; dotted where concealed.
- Strike and dip of eotaxitic foliation.
- Glacial erratic showing location and lithology.
- $\Delta_p$  pegmatite
- $\Delta_g$  granite
- $\Delta_{gp}$  pegmatitic granite
- $\Delta_d$  dolomite
- $\Delta$  lithology not determined

## MAP UNITS

### SEDIMENTARY DEPOSITS

- Qa** Alluvium (Holocene)
- Qf** Alluvial fan deposits (Holocene to Late Pleistocene)—Shown as Qf/Qf where overlain by loess.
- Qao** Outwash deposits (Late Pleistocene)—Shown as Qf/Qao where overlain by loess.
- Qafo** Older alluvial fan deposits (Late Pleistocene)—Shown as Qf/Qafo where overlain by loess.

### EOLIAN DEPOSITS

- Ql** Loess (Pleistocene)—Massive silt, clay, and fine sand; used in combination with other unit symbols where they are concealed under a meter or more of loess.

### MASS WASTING DEPOSITS

- Qls** Landslides (Quaternary)

### GLACIAL DEPOSITS

- Qm1** Lateral moraine (Pleistocene)
- Qme1** Younger end moraine (Late Pleistocene)—Deposits are possibly of Pinedale age.
- Qme2** End moraine (Pleistocene)—Piedmont deposits at the mouth of Teton Canyon; possibly of Bull Lake age.
- Qgt** Till, undivided (Pleistocene)

### VOLCANIC ROCKS




- Qyh** Huckleberry Ridge Tuff of the Yellowstone Group (early Pleistocene)—Shown as Qf/Qyh where overlain by loess.
- Tc** Conant Creek Tuff of the Heise volcanic field (late Miocene)

### SEDIMENTARY ROCKS

- Mm** Madison Group (Mississippian)

*This Technical Report is independent mapping by Glenn F. Embree. Its content and format may not conform to IGS standards.*

**Base Map Credit**  
Base: USGS 1:24,000-scale quadrangle, 1965, downloaded from USGS US Topo.  
Topography by photogrammetric methods from aerial photographs taken 1963. Field checked 1965.  
Projection: Idaho coordinate system, east zone (Transverse Mercator), 1927 North American Datum.  
10,000-foot grid ticks based on Idaho coordinate system, east zone and Wyoming coordinate system, west zone.  
1000-meter Universal Transverse Mercator grid ticks, zone 12. Declination from NOAA National Geophysical Data Center.



Field work conducted 2001.  
<sup>1</sup>Department of Geology, Brigham Young University-Idaho, Rexburg, ID 83460-0510.  
Digital cartography by Jane S. Freed at the Idaho Geological Survey's Digital Mapping Lab.  
Technical review status: Author only.  
Map version 1-16-2015.  
PDF (Acrobat Reader) map may be viewed online at [www.idahogeology.org](http://www.idahogeology.org).

# Appendix D: NUTRIENT MASS BALANCE SPREADSHEETS

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	4.25E+04	98.1
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.0
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.04E+02	0.9
Aquifer Width Perpendicular to Flow (ft)	380	Site-specific		<b>Total Water Volume</b>	<b>4.33E+04</b>	
Parcel Area (acres)	2.51	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.46E+08	91.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	8.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.59E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 1</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.35E+04	97.6
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	1.2
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.04E+02	1.2
Aquifer Width Perpendicular to Flow (ft)	300	Site-specific		<b>Total Water Volume</b>	<b>3.43E+04</b>	
Parcel Area (acres)	2.51	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.15E+08	89.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	10.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.29E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 2</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.35E+04	97.6
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	1.2
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.09E+02	1.2
Aquifer Width Perpendicular to Flow (ft)	300	Site-specific		<b>Total Water Volume</b>	<b>3.43E+04</b>	
Parcel Area (acres)	2.54	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.15E+08	89.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	10.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.23E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.29E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 3</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.91E+04	97.9
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.0
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.12E+02	1.0
Aquifer Width Perpendicular to Flow (ft)	350	Site-specific		<b>Total Water Volume</b>	<b>3.99E+04</b>	
Parcel Area (acres)	2.56	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.6</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.34E+08	90.9
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	9.0
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.24E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.48E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.


**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

**Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)**

Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$  (inches/yr) = (TAP)<sup>2</sup> \* 0.0046  
TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 4</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	4.25E+04	98.1
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.0
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.04E+02	0.9
Aquifer Width Perpendicular to Flow (ft)	380	Site-specific		<b>Total Water Volume</b>	<b>4.33E+04</b>	
Parcel Area (acres)	2.51	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.46E+08	91.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	8.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.59E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 5</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	





**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	7.37E+04	98.2
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	0.6
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	9.47E+02	1.3
Aquifer Width Perpendicular to Flow (ft)	660	Site-specific		<b>Total Water Volume</b>	<b>7.51E+04</b>	
Parcel Area (acres)	5.88	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.6</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>5.9</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	2.54E+08	94.9
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	5.0
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	2.84E+05	0.1
				<b>Total Nitrate Mass</b>	<b>2.67E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 6</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	4.36E+04	98.0
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	0.9
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.85E+02	1.1
Aquifer Width Perpendicular to Flow (ft)	390	Site-specific		<b>Total Water Volume</b>	<b>4.45E+04</b>	
Parcel Area (acres)	3.01	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>3.0</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.50E+08	91.8
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	8.1
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.45E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.63E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP * 0.0046$  (inches/yr) = (TAP)<sup>2</sup> \* 0.0046  
TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 7</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	9.22E+04	99.0
Hydraulic Gradient	0.015	Site-specific		Effluent	4.14E+02	0.4
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	5.54E+02	0.6
Aquifer Width Perpendicular to Flow (ft)	495	Site-specific		<b>Total Water Volume</b>	<b>9.31E+04</b>	
Parcel Area (acres)	3.44	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.5</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>3.4</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	3.17E+08	95.9
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	4.0
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.66E+05	0.1
				<b>Total Nitrate Mass</b>	<b>3.30E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 8</b>	<b>Parcel Identification</b>
<b>3/18/2025</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	5.03E+04	97.9
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	0.8
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	6.78E+02	1.3
Aquifer Width Perpendicular to Flow (ft)	450	Site-specific		<b>Total Water Volume</b>	<b>5.14E+04</b>	
Parcel Area (acres)	4.21	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.6</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>4.2</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.73E+08	92.8
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	7.1
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	2.04E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.86E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 9</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	5.03E+04	98.4
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	0.8
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.04E+02	0.8
Aquifer Width Perpendicular to Flow (ft)	450	Site-specific		<b>Total Water Volume</b>	<b>5.11E+04</b>	
Parcel Area (acres)	2.51	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.6</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.73E+08	92.8
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	7.1
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.86E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 10</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	5.03E+04	98.4
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	0.8
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.04E+02	0.8
Aquifer Width Perpendicular to Flow (ft)	450	Site-specific		<b>Total Water Volume</b>	<b>5.11E+04</b>	
Parcel Area (acres)	2.51	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.6</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.73E+08	92.8
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	7.1
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.86E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 11</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	5.03E+04	98.3
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	0.8
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.67E+02	0.9
Aquifer Width Perpendicular to Flow (ft)	450	Site-specific		<b>Total Water Volume</b>	<b>5.12E+04</b>	
Parcel Area (acres)	2.9	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.6</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.9</b>	
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>			
Natural Recharge rate (inches/yr)	1.65	Site-specific				
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>	<b>Mass (mg)</b>	<b>% of Total</b>
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific		Background GW Nitrate Mass	1.73E+08	92.8
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	7.1
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Recharge Nitrate Mass	1.40E+05	0.1
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	<b>Total Nitrate Mass</b>	<b>1.86E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 12</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	5.19E+04	97.3
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	0.8
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	1.04E+03	1.9
Aquifer Width Perpendicular to Flow (ft)	465	Site-specific		<b>Total Water Volume</b>	<b>5.34E+04</b>	
Parcel Area (acres)	6.46	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.6</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>6.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.79E+08	92.9
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	6.9
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	3.12E+05	0.2
				<b>Total Nitrate Mass</b>	<b>1.92E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP * 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 13</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.74E+04	97.8
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.1
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.25E+02	1.1
Aquifer Width Perpendicular to Flow (ft)	335	Site-specific		<b>Total Water Volume</b>	<b>3.83E+04</b>	
Parcel Area (acres)	2.64	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.6</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.29E+08	90.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	9.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.28E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.42E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 14</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.74E+04	97.8
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	1.1
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.25E+02	1.1
Aquifer Width Perpendicular to Flow (ft)	335	Site-specific		<b>Total Water Volume</b>	<b>3.83E+04</b>	
Parcel Area (acres)	2.64	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.6</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.29E+08	90.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	9.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.28E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.42E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP * 0.0046$   
TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 15</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.74E+04	97.8
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.1
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.25E+02	1.1
Aquifer Width Perpendicular to Flow (ft)	335	Site-specific		<b>Total Water Volume</b>	<b>3.83E+04</b>	
Parcel Area (acres)	2.64	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.6</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.29E+08	90.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	9.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.28E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.42E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP * 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 16</b>	<b>Parcel Identification</b>
<b>2/7/2024</b>	<b>Date</b>
<b>3/18/2024</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	2.23E+04	96.9
Hydraulic Gradient	0.009	Site-specific		Efluent	0.00E+00	0.0
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	7.11E+02	3.1
Aquifer Width Perpendicular to Flow (ft)	200	Site-specific		<b>Total Water Volume</b>	<b>2.31E+04</b>	
Parcel Area (acres)	4.41	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	0.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.3</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>#DIV/0!</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>	<b>Mass (mg)</b>	<b>% of Total</b>
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific		Background GW Nitrate Mass	7.69E+07	99.7
Septic Tank Effluent Concentration (mg/l)	0.0	45.0	<b>Provide Justification</b>	Septic Tank Effluent Nitrate Mass	0.00E+00	0.0
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Recharge Nitrate Mass	2.13E+05	0.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	<b>Total Nitrate Mass</b>	<b>7.71E+07</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$  (inches/yr) = (TAP)<sup>2</sup> \* 0.0046  
TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 17</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.74E+04	97.8
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.1
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.25E+02	1.1
Aquifer Width Perpendicular to Flow (ft)	335	Site-specific		<b>Total Water Volume</b>	<b>3.83E+04</b>	
Parcel Area (acres)	2.64	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.6</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.29E+08	90.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	9.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.28E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.42E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 18</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.74E+04	97.8
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	1.1
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.25E+02	1.1
Aquifer Width Perpendicular to Flow (ft)	335	Site-specific		<b>Total Water Volume</b>	<b>3.83E+04</b>	
Parcel Area (acres)	2.64	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.6</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.29E+08	90.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	9.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.28E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.42E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 19</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.74E+04	97.8
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.1
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.25E+02	1.1
Aquifer Width Perpendicular to Flow (ft)	335	Site-specific		<b>Total Water Volume</b>	<b>3.83E+04</b>	
Parcel Area (acres)	2.64	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.7</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.6</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.29E+08	90.6
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	9.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.28E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.42E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 20</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.24E+04	97.5
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	1.2
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.32E+02	1.3
Aquifer Width Perpendicular to Flow (ft)	290	Site-specific		<b>Total Water Volume</b>	<b>3.32E+04</b>	
Parcel Area (acres)	2.68	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.8</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.7</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.11E+08	89.3
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	10.6
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.30E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.25E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP * 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 21</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.24E+04	97.5
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	1.2
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.04E+02	1.2
Aquifer Width Perpendicular to Flow (ft)	290	Site-specific		<b>Total Water Volume</b>	<b>3.32E+04</b>	
Parcel Area (acres)	2.51	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.8</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.11E+08	89.3
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	10.6
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.25E+08</b>	

**Instructions for Use**


Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP * 0.0046$   
 TAP is input in inches/yr.

<b>SITE INFORMATION</b>	
<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 22</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.24E+04	97.5
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.2
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.04E+02	1.2
Aquifer Width Perpendicular to Flow (ft)	290	Site-specific		<b>Total Water Volume</b>	<b>3.32E+04</b>	
Parcel Area (acres)	2.51	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.8</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.11E+08	89.3
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	10.6
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.25E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP * 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 23</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.24E+04	97.5
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.2
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.04E+02	1.2
Aquifer Width Perpendicular to Flow (ft)	290	Site-specific		<b>Total Water Volume</b>	<b>3.32E+04</b>	
Parcel Area (acres)	2.51	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.8</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.11E+08	89.3
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	10.6
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.25E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 24</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.24E+04	97.5
Hydraulic Gradient	0.009	Site-specific		Effluent	4.14E+02	1.2
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.06E+02	1.2
Aquifer Width Perpendicular to Flow (ft)	290	Site-specific		<b>Total Water Volume</b>	<b>3.32E+04</b>	
Parcel Area (acres)	2.52	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.8</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.11E+08	89.3
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	10.6
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.22E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.25E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 25</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	3.24E+04	97.5
Hydraulic Gradient	0.009	Site-specific		Efluent	4.14E+02	1.2
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.08E+02	1.2
Aquifer Width Perpendicular to Flow (ft)	290	Site-specific		<b>Total Water Volume</b>	<b>3.32E+04</b>	
Parcel Area (acres)	2.53	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	1.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>3.8</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>2.5</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	1.11E+08	89.3
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.33E+07	10.6
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.22E+05	0.1
				<b>Total Nitrate Mass</b>	<b>1.25E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$  (inches/yr) = (TAP)<sup>2</sup> \* 0.0046  
TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lot 26</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	1.21E+05	94.3
Hydraulic Gradient	0.009	Site-specific		Effluent	3.32E+03	2.6
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	4.02E+03	3.1
Aquifer Width Perpendicular to Flow (ft)	1080	Site-specific		<b>Total Water Volume</b>	<b>1.28E+05</b>	
Parcel Area (acres)	24.96	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	8.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>4.1</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>3.1</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	4.15E+08	79.5
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	1.06E+08	20.3
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	1.21E+06	0.2
				<b>Total Nitrate Mass</b>	<b>5.22E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).

As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1

**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.

**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lots 1-8</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	



**IDEQ LEVEL 1 NUTRIENT-PATHOGEN EVALUATION NITROGEN MASS-BALANCE SPREADSHEET**

V. 1.3 5/2/2002

This spreadsheet is based on the mass balance approach documented in: 1985.Bauman, B.J. and W.M. Schaefer. Estimating Ground-Water Quality Impacts From On-Site Sewage Treatment Systems. In Proceedings of 5th Northwest On-Site Wastewater Treatment Shortcourse, September 10-11, 1985. University of Washington, Seattle, WA. Pages 23-41. See **Instructions for Use** below.

<b>INPUT</b>				<b>OUTPUT</b>		
<b>Water Budget</b>	<b>Input Value</b>	<b>Default Value</b>		<b>Yearly Water Budget</b>	<b>Volume (m<sup>3</sup>)</b>	<b>% of Total</b>
Hydraulic Conductivity (ft/day)	80.000	Site-specific		Ground Water	1.58E+05	90.9
Hydraulic Gradient	0.009	Site-specific		Efluent	7.05E+03	4.1
Mixing Zone Thickness (ft)	15	15	<b>Default</b>	Recharge	8.72E+03	5.0
Aquifer Width Perpendicular to Flow (ft)	1415	Site-specific		<b>Total Water Volume</b>	<b>1.74E+05</b>	
Parcel Area (acres)	54.1	Site-specific				
Percent of Parcel That Is Impervious (Percent)	5	Site-specific		<b>Point of Compliance Nitrate Concentration Goal (mg/l)</b>	<b>4.4</b>	
Current/Acceptable Number of Homes in Parcel	17.0	Site-specific				
Septic Tank Effluent (gallons/d/home)	300	300	<b>Default</b>	<b>Avg. Downgradient Nitrate Concentration in GW (mg/l)</b>	<b>4.4</b>	
Natural Recharge rate (inches/yr)	1.65	Site-specific		<b>Current/Acceptable Lot Size (Acres)</b>	<b>3.2</b>	
<b>Nitrogen Budget</b> (all concentrations represent nitrate nitrogen)				<b>Yearly Nitrogen Budget</b>		
Upgradient Ground Water Concentration (mg/l)	3.4	Site-specific			<b>Mass (mg)</b>	<b>% of Total</b>
Septic Tank Effluent Concentration (mg/l)	32.0	45.0	<b>Provide Justification</b>	Background GW Nitrate Mass	5.44E+08	70.4
Denitrification Rate (decimal fraction)		0	<b>Default</b>	Septic Tank Effluent Nitrate Mass	2.25E+08	29.2
Nitrate in Natural Recharge (mg/l)	0.3	0.3	<b>Default</b>	Recharge Nitrate Mass	2.62E+06	0.3
				<b>Total Nitrate Mass</b>	<b>7.72E+08</b>	

**Instructions for Use**

Input parameter values appropriate to conditions at the site under consideration are entered in the **blue shaded cells** on the **INPUT** side of the spreadsheet. These input values form the basis for calculating yearly water and nitrogen budgets. Default values for selected parameters are provided, as described in the accompanying N-P guidance. Selecting values other than these defaults will require providing adequate justification. Sources of water and nitrogen include ground water inflow from upgradient, natural recharge on pervious portions of the site, and from septic tank effluent. The total yearly nitrogen mass input is then divided by the total yearly volume of water available to recharge groundwater to arrive at an estimated **Average Downgradient Nitrate Concentration in GW** (shown in the **OUTPUT** side of the spreadsheet).


As values are input into the **blue shaded cells** the totals and percent of total for various components of the water and nitrogen budgets are calculated and shown on the **OUTPUT** side of the spreadsheet. The **Avg. Downgradient Nitrate Concentration in GW** is also calculated. The Density button allows the calculation of both the Acceptable Number of Homes in the Parcel (shown in the **INPUT** area) as well as the acceptable lot size. Clicking the Density button opens an input box that allows the input of the **Point of Compliance Nitrate Concentration Goal**. The number of homes in the parcel is then adjusted to meet the specified goal. This calculation can be redone iteratively along with changing other site input parameters to examine the resultant impact on nitrate concentrations.

**Aquifer Width Perpendicular to Flow:** For land development projects not completely oriented perpendicular to ground water flow, the site specific aquifer width value is determined using the average property width that is perpendicular to flow.

<b>Ranges of Hydraulic Conductivity (K) for Unconsolidated Sediments (feet/day)</b>	
Silt and sandy silt	0.003 to 0.3
Silty sands and fine sands	0.03 to 3
Well-sorted sands and glacial outwash	3 to 300
Well-sorted gravel	30 to 3000
<b>Typical Range of Hydraulic Gradient</b>	0.0001 to 0.1


**Natural Recharge Rate (NRR)** can be estimated from total annual precipitation (TAP) using the equation:  $NRR = TAP \times 0.0046$ . TAP is input in inches/yr.


**SITE INFORMATION**

<b>JC Ranches Subdivision</b>	<b>Site Name</b>
<b>Lots 9-26</b>	<b>Parcel Identification</b>
<b>3/18/2024</b>	<b>Date</b>
<b>Adrienne Lemmers, PE Y2 Consultants, LLC</b>	<b>Prepared By</b>
Disclaimer: Considerable care was exercised in developing this software. However, the Idaho Department of Environmental Quality makes no warranty regarding its accuracy and shall not be held liable for any damages resulting from its use.	
	

# Appendix E: POTENTIOMETRIC MAPPING DATA







**Table 6**  
**Model Calibration Targets**  
**Teton Basin Ground-water Model**

USGS Designation	Model Designation	State Plane Coordinates		Water Level (ft, msl)	Date	Accuracy Datum (ft)
		x	y			
433439111090401	1	925076	697983	6077.00	05/09/94	5
433502111070601	2	933738	700425	6085.00	08/08/90	10
433604111072701	3	932097	706675	6045.00	01/10/94	5
433624111091401	4	924204	708654	6040.00	02/02/90	5
433640111102901	5	918677	710155	6029.11	07/27/99	40
433828111060201	6	938214	721298	6090.00	05/22/97	5
433832111071901	7	932517	721663	6059.10	05/06/02	5
433911111054701	8	939191	725721	6065.00	05/08/00	5
434008111104801	9	917022	731170	6022.00	05/18/90	5
434032111045001	10	943396	734052	6093.55	09/12/96	0.01
434047111065401	12	934172	735354	6084.23	09/14/98	10
434100111120701	13	911573	737813	6021.80	05/21/93	10
434110111062301	14	936416	737753	6081.00	06/19/00	5
434142111113701	15	913311	740641	6011.77	05/06/02	5
434323111133601	17	904442	750745	6007.27	05/07/02	5
434354111055101	18	938584	754369	6082.19	05/06/02	5
434501111035301	20	947340	761294	6203.96 (1)	*	10
434503111034701	21	947529	761450	6202.13	05/06/02	5
434514111025501	22	951346	762630	6250.00	10/12/00	5
434627111043401	23	944037	769898	6175.00	07/25/01	5
434651111041901	24	945035	772317	6168.44	05/07/02	5
434708111142701	26	900486	773558	5969.00	10/19/93	2
434746111072001	27	931732	777723	6130.00	06/24/96	5
434931111110201	30	915288	788202	5969.81	05/08/02	5
434936111143601	31	899525	788750	5828.15	03/18/98	0.01
434937111140701	32	901743	788629	5866.26	06/03/91	10
435016111064401	33	934152	793028	6180.00	10/22/98	5
435110111074101	34	929915	798444	6180.39	05/07/02	5
434827111122701	35	909745	781569	5922.00	10/24/99	5
434749111093401	36	922351	777957	6024.00	03/09/94	5

Highlighted wells were used to set a boundary for the potentiometric surface area. Other wells were initially included, but are very far north or south of the site (several miles) and were removed.

Data points in the 3D TIN model to generate the potentiometric surface. The USGS wells were from the Nicklin Table 6 on the previous sheet. Other wells were selected from the IDWR website and shown on the following pages.

Name	Field Code	Terrain Mo...	Easting	Northing	Elevation
USGS_24	PNT	Spot	945035.000'	772317.000'	6168.440'
USGS_26	PNT	Spot	900486.000'	773558.000'	5969.000'
USGS_27	PNT	Spot	931732.000'	777723.000'	6130.000'
USGS_36	PNT	Spot	922351.000'	777957.000'	6024.000'
D0048827	PNT	Spot	929899.380'	771912.320'	6093.860'
Well ID 327944	PNT	Spot	926398.604'	768975.502'	6055.000'
Well ID 379279	PNT	Spot	925102.604'	771613.927'	6056.000'
Cache Townsite	PNT	Spot	922307.950'	771962.529'	6034.500'
Well ID 327497	PNT	Spot	926413.513'	772976.429'	6091.000'
Dry Creek Ranch	PNT	Spot	933656.326'	767667.156'	6120.000'
431234	PNT	Spot	911214.408'	760115.976'	5960.000'
327369	PNT	Spot	917244.676'	760982.530'	5986.000'
422151	PNT	Spot	917229.152'	764942.198'	6002.700'
Sage Creek Drive	PNT	Spot	922889.102'	766650.989'	6028.000'
327879	PNT	Spot	933147.920'	761119.283'	6048.000'
327680	PNT	Spot	929043.180'	772966.110'	6094.000'
460347	PNT	Spot	935087.871'	774552.521'	6155.000'
327371	PNT	Spot	921203.983'	768979.619'	6013.000'
470088	PNT	Spot	920697.327'	777434.955'	6023.000'
424205	PNT	Spot	915714.757'	772941.887'	5997.000'
469565	PNT	Spot	923872.093'	760615.421'	6036.000'
328354	PNT	Spot	905375.200'	779531.096'	5941.000'

Well point data used in the potentiometric surface. Logs are provided for individual wells that were used - this happened when there was only one shallower well in an area. When multiple wells were used, the number, date range, and average water level was used in the mapping.

WellID - 4199166  
PermitID - 849279  
MetalTagNumber - D0048827  
Construction Date - 10/01/2007  
Static water level depth - 20' bgs  
Elevation from survey - 6113.86  
Water level depth = 6093.86  
x= 929899.38  
y= 771912.32

WellID 327944  
PermitID 702246  
Construction Date - 4/8/1993  
Static water level - 26' bgs  
Location is by quarter-quarter  
Lat:43.772108  
Long:-111.143584  
x= 926398.604  
y= 768975.502  
Surface = 6081 from topo map  
Water level depth = 6055

WellID - 379279  
PermitID - 808484  
MetalTagNumber - D0027575  
Construction Date - 10/30/2003  
Static water level depth - 20' bgs  
Surface = 6076 from topo map  
Water level depth = 6056  
Lat:43.779389  
Long:-111.148367  
x= 925102.604  
y= 771613.927

The Cache Townsite subdivision located at the corner of W 4000 N and N 3000 W has 10 well records from 2007 through 2022. All of these wells were drilled in the range of 60 to 100 feet bgs. The water level from the logs was averaged due to their proximity. The water levels range from 10 to 20 feet bgs with an average of 15.5 feet bgs.

Surface = 6050 from topo map  
Water level depth = 6034.5  
Lat:43.780439  
Long:-111.158931  
x= 922307.950  
y= 771962.529

WellID - 327497  
PermitID - 702556  
MetalTagNumber -  
Construction Date - 9/17/1994  
Static water level depth - 15' bgs  
Surface = 6106 from topo map  
Water level depth = 6091  
Lat:43.783082  
Long:-111.1433404  
x= 926413.513  
y= 772976.429

Dry Creek Ranch  
8 wells within subdivision drilled from 2005 to 2023. Shallow water levels are at 20' bgs.  
Average Depth to Static Water Level = 20  
Surface El = 6140 at about the center of the subdivision  
Lat:43.768270  
Long:-111.116174  
x= 933656.326  
y= 767667.156

Well right next to the river

WellID - 431234

PermitID - 861998

MetalTagNumber - D0059712

Construction Date - 9/12/2011

Static water level depth - 18' bgs

Surface El = 5978

Lat:43.748306

Long:-111.201453

x= 911214.408

y= 760115.976

Wells along Sage Creek Drive

20' and 24' depth, one anomalous well had a depth greater than the completion depth and was not used. Wells were drilled in 2020 and 2023.

Use a depth of 22'

Surface El=6050

Lat: 43.765850

Long: -111.156976

x=922889.102

y=766650.989

Well just east of N 4000 W - located in stream bed

WellID - 327369

PermitID - 702433

MetalTagNumber -

Construction Date - 4/27/1994

Static water level depth - 18' bgs

Surface El = 6004

Lat:43.750488

Long:-111.178596

x= 917244.676

y=760982.530

WellID - 327879

PermitID - 702183

MetalTagNumber -

Construction Date -10/17/1992

Static water level depth - 68' bgs

Surface = 6116 from topo map

Water level depth = 6048

Lat:43.750327

Long:-111.118412

x= 933147.920

y= 761119.283

This well is much deeper than most wells used. Used as a south boundary point and not used for average slope for mass-balance spreadsheets. |

3 wells, just south of N 4000 W & W 3000 N

One drilled in 1993 and the other two in 2008

WellID - 422151

PermitID - 852378

MetalTagNumber -D0049730

Water levels 10, 13, and 20

Static water level depth = 14.3

Surface EL = 6017

Lat:43.761350

Long:-111.178476

x= 917229.152

y=764942.198

WellID - 327680

PermitID - 701985

MetalTagNumber -

Construction Date -8/20/1991

Static water level depth - 15' bgs

Surface = 6109 from topo map

Water level depth = 6094

Lat:43.750327

Long:-111.118412

x= 933147.920

y= 761119.283

WellID - 460347  
PermitID - 895654  
MetalTagNumber - D0083627  
Construction Date -8/31/2020  
Static water level depth - 20' bgs  
Surface = 6175 from topo map  
Water level depth = 6155  
x= 935085.45  
y= 774535.30

WellID - 327371  
PermitID - 702435  
MetalTagNumber -  
Construction Date -4/28/1994  
Static water level depth - 19' bgs  
Surface = 6032 from topo map  
Water level depth = 6013  
x= 921203.98'  
y= 768979.62'

WellID - 470088  
PermitID - 905888  
MetalTagNumber - D0092439  
Construction Date -6/27/2022  
Static water level depth - 20' bgs  
Surface = 6043 from topo map  
Water level depth = 6023  
x= 920697.33'  
y= 777434.96

WellID - 424205  
PermitID - 854539  
MetalTagNumber - D0049755  
Construction Date -12/29/2008  
Static water level depth - 20' bgs  
Surface = 6017 from topo map  
Water level depth = 5997  
x=915714.76  
y=772941.89

WellID - 469565  
PermitID - 905346  
MetalTagNumber - D0091772  
Construction Date -5/26/2022  
Static water level depth - 4' bgs  
Surface = 6040 from topo map  
Water level depth = 6036  
x=923872.09  
y=760615.42

WellID - 328354  
PermitID - 701878  
MetalTagNumber -  
Construction Date -10/4/1990  
Static water level depth - 5' bgs  
Surface = 5946 from topo map  
Water level depth = 5941  
x=905375.20  
y=779531.10

IDAHO DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

22

Office Use Only			
Well ID No.	_____		
Inspected by	_____		
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat: : : :	Long: : : :		

1. WELL TAG NO. D 0048827  
 DRILLING PERMIT NO. \_\_\_\_\_  
 Water Right or Injection Well No. \_\_\_\_\_

2. OWNER:  
 Name Shawn Perkins  
 Address 307 North Hwy 33  
 City Driggs State ID Zip 83455

3. LOCATION OF WELL by legal description:  
 You must provide address or Lot, Blk, Sub. or Directions to well.  
 Twp. 5 North  or South   
 Rge. 45 East  or West   
 Sec. 10 1/4 NW 1/4 NE 1/4  
 Gov't Lot \_\_\_\_\_  
 County Teton  
 Lat: 43:46:869 Long: 111:07:899  
 Address of Well Site 400 N. 95 West  
 City Driggs  
(Give at least name of road - Distance to Road or Landmark)  
 Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>benzite</u>	<u>0'</u>	<u>18'</u>	<u>450 lbs</u>	<u>overbore</u>

Was drive shoe used?  Y  N Shoe Depth(s) 100'  
 Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6"</u>	<u>0'</u>	<u>100'</u>	<u>290</u>	<u>steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
 Packer  Y  N Type \_\_\_\_\_

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method \_\_\_\_\_  
 Screen Type & Method of Installation \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
20 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
 Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

12. WELL TESTS:  
 Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
 Water Quality test or comments: \_\_\_\_\_

Depth first Water Encounter \_\_\_\_\_

13. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8"</u>	<u>0'</u>	<u>18'</u>	<u>clay-gravels</u>		<input checked="" type="checkbox"/>
<u>6"</u>	<u>18'</u>	<u>45'</u>	<u>clay-gravels</u>	<input checked="" type="checkbox"/>	
<u>6"</u>	<u>45'</u>	<u>60'</u>	<u>clay-sand-gravels</u>	<input checked="" type="checkbox"/>	
<u>6"</u>	<u>60'</u>	<u>80'</u>	<u>clay-sand-gravels</u>	<input checked="" type="checkbox"/>	
<u>6"</u>	<u>80'</u>	<u>100'</u>	<u>clay-gravels</u>	<input checked="" type="checkbox"/>	

RECEIVED  
 OCT 11 2007

Department of Water Resources  
 Eastern Region

Completed Depth 100' (Measurable)  
 Date: Started 10-2-07 Completed 10-2-07

14. DRILLER'S CERTIFICATION  
 I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Deming Drilling Firm No. 518  
 Principal Driller Deming Drilling Date 10-3-07  
 and  
 Driller or Operator II Deming Drilling Date 10-3-07  
 Operator I John Deming Date 10-5-07  
 Principal Driller and Rig Operator Required.  
 Operator I must have signature of Driller/Operator II.





DMP

IDAHO DEPARTMENT OF WATER RESOURCES  
WELL DRILLER'S REPORT

Office Use Only			
Well ID No.	_____		
Inspected by	_____		
Twp	Rge	Sec	
_____	_____	_____	
_____	1/4	1/4	1/4
Lat:	:	Long:	:

1. WELL TAG NO. D 0027575  
DRILLING PERMIT NO. \_\_\_\_\_  
Water Right or Injection Well No. 22

2. OWNER:  
Name Harold Gee  
Address 2272 E Hwy 33  
City Sugar City State ID Zip 83448

3. LOCATION OF WELL by legal description:  
You must provide address or Lot, Blk, Sub. or Directions to well.  
Twp. S North  or South   
Rge. 49 East  or West   
Sec. 9 1/4 NW 1/4 NE 1/4  
Gov't Lot \_\_\_\_\_ County teton  
Lat: : : Long: : :  
Address of Well Site 375 N 300W  
City Driggs  
Lt. \_\_\_\_\_ Blk \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>400 #</u>	<u>overbore</u>

Was drive shoe used?  Y  N Shoe Depth(s) \_\_\_\_\_  
Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>1 1/2"</u>	<u>1</u>	<u>100</u>	<u>250</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
Packer  Y  N Type \_\_\_\_\_

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method \_\_\_\_\_  
Screen Type & Method of Installation \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
20' ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

12. WELL TESTS:  
 Pump  Bailer  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
Water Quality test or comments: \_\_\_\_\_

13. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8"</u>	<u>0'</u>	<u>20'</u>	<u>Dirt, clay, gravel</u>		<u>X</u>
<u>6"</u>	<u>20'</u>	<u>68'</u>	<u>clay gravel</u>	<u>X</u>	
	<u>68'</u>	<u>90'</u>	<u>clay sand gravel</u>	<u>X</u>	
	<u>90'</u>	<u>100'</u>	<u>clay gravel</u>	<u>X</u>	

RECEIVED  
DEC 08 2003  
Department of Water Resources  
Eastern Region

Completed Depth 100' (Measurable)  
Date: Started 10/28/03 Completed 10/30/03

14. DRILLER'S CERTIFICATION  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Denning Well Drilling Firm No. 518  
Principal Driller James Denning Date 11-3-03  
and  
Driller or Operator II James Denning Date 10/30/03  
Operator I \_\_\_\_\_ Date \_\_\_\_\_

Principal Driller and Rig Operator Required  
Operator I must have signature of Driller/Operator II.

IDAHO DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Use Typewriter  
or  
Ball Point Pen

55899

1. DRILLING PERMIT NO. 22-94-E-167  
Other IDWR No. \_\_\_\_\_

2. OWNER: Kent Hale  
Name Kent Hale  
Address P.O. Box 117  
City Tetonia State Id Zip 83452

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N		Twp. <u>5</u> North <input checked="" type="checkbox"/> or South <input type="checkbox"/>	
E		Rge. <u>15</u> East <input checked="" type="checkbox"/> or West <input type="checkbox"/>	
S		Sec. <u>3</u> SE 1/4 <input checked="" type="checkbox"/> SW 1/4 <input type="checkbox"/>	
W		Gov't Lot _____ County <u>TETON</u>	

Address of Well Site 178 W. 400th  
Pucksaddle Rd. City Tetonia  
(Give at least name of road + Distance to Road or Landmark)

Lt. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

4. PROPOSED USE:

- Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK

- New Well  Modify or Repair  Replacement  Abandonment

6. DRILL METHOD

- Mud Rotary  Air Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
<u>Bentonite</u>	<u>0</u>	<u>20</u>	<u>3</u>	<u>Over bore</u>

Was drive shoe used? Y  N

Was drive shoe seal tested? Y  N  How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6</u>	<u>0</u>	<u>60</u>	<u>250</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

9. PERFORATIONS/SCREENS NONE

- Perforations Method \_\_\_\_\_  
 Screens Screen Type \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

15 ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

11. WELL TESTS:

- Pump  Bailer  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
<u>35</u>	<u>55</u>	<u>85</u>	<u>1 Hr</u>

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_

Water Quality test or comments: Clean + good

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>6</u>	<u>0</u>	<u>20</u>	<u>sand + gravel (12' H<sub>2</sub>O)</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>6</u>	<u>20</u>	<u>30</u>	<u>sand</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>6</u>	<u>30</u>	<u>40</u>	<u>washed gravel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<u>6</u>	<u>40</u>	<u>60</u>	<u>sand + gravel</u>	<input type="checkbox"/>	<input type="checkbox"/>

RECEIVED  
DEC 23 1994  
Department of Water Resources

RECEIVED  
DEC 14 1994  
Department of Water Resources  
Eastern District Office

RECEIVED  
OCT 14 1994  
Department of Water Resources  
Eastern District Office

MAY 08 1995

Completed Depth 60' (Measurable)  
Date: Started 9-18-94 Completed 9-18-94

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Teton Water Works Firm No. 506

Firm Official \_\_\_\_\_ Date 10-12-94

and  
Supervisor or Operator [Signature] Date \_\_\_\_\_

(Sign once if Firm Official & Operator)

# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

22

**1. WELL TAG NO. D** 0059712

Drilling Permit No. \_\_\_\_\_  
Water right or injection well # \_\_\_\_\_

**2. OWNER:** Willow Bend LLC % Derek Hara

Name Derek Hara  
Address P.O. BOX 761  
City Victor State ID Zip 83455

**3. WELL LOCATION:**

Twp. 5 North  or South  Rge. 45 East  or West   
Sec. 19 10 acres 1/4 40 acres SW 1/4 NW 1/4

Gov't Lot \_\_\_\_\_ County Teton  
Lat. 43° 44' 912" (Deg. and Decimal minutes)  
Long. 111° 12' 032" (Deg. and Decimal minutes)  
Address of Well Site 6000 W 2000 N

(Give at least name of road + Distance to Road or Landmark) City Driggs  
Lot. \_\_\_\_\_ Blk. \_\_\_\_\_ Sub. Name \_\_\_\_\_

**4. USE:**

Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

**5. TYPE OF WORK:**

New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

**6. DRILL METHOD:**

Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

**7. SEALING PROCEDURES:**

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
Bentonite	0	38	800#	overbore 10"

**8. CASING/LINER:**

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6"	+2	58	250	steel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) 58'

**9. PERFORATIONS/SCREENS:**

Perforations  Y  N Method \_\_\_\_\_  
Manufactured screen  Y  N Type \_\_\_\_\_  
Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_

Packer  Y  N Type \_\_\_\_\_

**10. FILTER PACK:**

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

**11. FLOWING ARTESIAN:**

Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

**12. STATIC WATER LEVEL and WELL TESTS:**

Depth first water encountered (ft) 36' Static water level (ft) 18'  
Water temp. (°F) \_\_\_\_\_ Bottom hole temp. (°F) \_\_\_\_\_  
Describe access port \_\_\_\_\_

**Well test:**

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
50'	5+	

**Test method:**

Pump  Bailer  Air  Flowing artesian

Water quality test or comments: \_\_\_\_\_

**13. LITHOLOGIC LOG and/or repairs or abandonment:**

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10"	0	5	overburden/clay		
	5	16	Clay + Gravel		
	16	36	Clay		
	36	38	Sand + Gravel		
6"	38	42	Sand + Gravel		
	42	55	Clay		
	55	58	Gravel + Sediment		

RECEIVED  
OCT 27 2011  
Department of Water Resources  
Eastern Region

Completed Depth (Measurable): 58'  
Date Started: 9-13-11 Date Completed: 9-13-11

**14. DRILLER'S CERTIFICATION:**

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Denning Drilling Co. No. 518

\*Principal Driller David Denning Date 9-16-11

\*Driller \_\_\_\_\_ Date \_\_\_\_\_

\*Operator II Tyler Hill Date 9-15-11

Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.













# IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

1. WELL TAG NO. D D0092439

Drilling Permit No. \_\_\_\_\_  
Water right or injection well # \_\_\_\_\_

2. OWNER: Brian mau

Name \_\_\_\_\_  
Address Box 156  
City Victor State \_\_\_\_\_ Zip \_\_\_\_\_

3. WELL LOCATION:

Twp. S North  or South  Rge. 45 East  or West

Sec. 5 1/4 ne 1/4 ne 1/4

Gov't Lot \_\_\_\_\_ County Teton

Lat. 43 ° 47 ' 7304 (Deg. and Decimal minutes)  
Long. 111 ° 09 ' 8862 (Deg. and Decimal minutes)

Address of Well Site 4851 N 3250 W  
City Teton

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  Thermal  Injection  
 Other \_\_\_\_\_

5. TYPE OF WORK:  
 New well  Replacement well  Modify existing well  
 Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Mud Rotary  Cable  Other \_\_\_\_\_

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method/procedure
<u>Bentontite</u>	<u>0</u>	<u>38</u>	<u>1100</u>	<u>10" form casing</u>

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
<u>6</u>	<u>12</u>	<u>100</u>	<u>.250</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Was drive shoe used?  Y  N Shoe Depth(s) 100

9. PERFORATIONS/SCREENS:  
Perforations  Y  N Method \_\_\_\_\_  
Manufactured screen  Y  N Type \_\_\_\_\_  
Method of installation \_\_\_\_\_

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
Packer  Y  N Type \_\_\_\_\_

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft <sup>3</sup> )	Placement method

11. FLOWING ARTESIAN:  
Flowing Artesian?  Y  N Artesian Pressure (PSIG) \_\_\_\_\_  
Describe control device \_\_\_\_\_

12. STATIC WATER LEVEL and WELL TESTS:  
Depth first water encountered (ft) 40 Static water level (ft) 20  
Water temp. (°F) \_\_\_\_\_ Bottom hole temp. (°F) \_\_\_\_\_  
Describe access port \_\_\_\_\_

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)	Pump	Bailer	Air	Flowing artesian
	<u>25</u>	<u>20</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Water quality test or comments: \_\_\_\_\_

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
<u>10</u>	<u>0</u>	<u>38</u>	<u>Clay, gravel</u>		<input checked="" type="checkbox"/>
<u>6</u>	<u>38</u>	<u>80</u>	<u>Clay, Sand, gravel</u>	<input checked="" type="checkbox"/>	
	<u>80</u>	<u>100</u>	<u>gravel, sand</u>	<input checked="" type="checkbox"/>	

RECEIVED

JUL 25 2022

Department of Water Resources  
Eastern Region

Completed Depth (Measurable): 100  
Date Started: 6/27/22 Date Completed: 6/28/22

14. DRILLER'S CERTIFICATION:  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Daniel Denny Drilling Co. No. 518  
\*Principal Driller [Signature] Date 6-29-22  
\*Driller [Signature] Date 6/28/22  
\*Operator II \_\_\_\_\_ Date \_\_\_\_\_  
Operator I \_\_\_\_\_ Date \_\_\_\_\_

\* Signature of Principal Driller and rig operator are required.

IDAHO DEPARTMENT OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Office Use Only  
Well ID No. \_\_\_\_\_  
Inspected by \_\_\_\_\_  
Twp \_\_\_\_\_ Rge \_\_\_\_\_ Sec \_\_\_\_\_  
1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 \_\_\_\_\_  
Lat: : : Long: : :

22

1. WELL TAG NO. D 0049755  
DRILLING PERMIT NO. \_\_\_\_\_  
Water Right or Injection Well No. \_\_\_\_\_

2. OWNER:  
Name Roy Bell  
Address 450N 450W  
City Tetonia State Id Zip 83452

3. LOCATION OF WELL by legal description:  
You must provide address or Lot, Blk, Sub. or Directions to well.  
Twp. 5 North  or South   
Rge. 45 East  or West   
Sec. 6 1/4 SE 1/4 SE 1/4  
Gov't Lot \_\_\_\_\_ 10 acres \_\_\_\_\_ 40 acres \_\_\_\_\_ 160 acres \_\_\_\_\_  
Lat: : : Long: : :  
Address of Well Site 441 N 450W  
City Tetonia

4. USE:  
 Domestic  Municipal  Monitor  Irrigation  
 Thermal  Injection  Other \_\_\_\_\_

5. TYPE OF WORK check all that apply (Replacement etc.)  
 New Well  Modify  Abandonment  Other \_\_\_\_\_

6. DRILL METHOD:  
 Air Rotary  Cable  Mud Rotary  Other \_\_\_\_\_

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
<u>Bentonite</u>	<u>0</u>	<u>20'</u>	<u>500LBS</u>	<u>Over Bore</u>

Was drive shoe used?  Y  N Shoe Depth(s) 60  
Was drive shoe seal tested?  Y  N How? \_\_\_\_\_

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6"</u>	<u>+1</u>	<u>59'</u>	<u>250"</u>	<u>Steel</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Length of Headpipe \_\_\_\_\_ Length of Tailpipe \_\_\_\_\_  
Packer  Y  N Type \_\_\_\_\_

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method \_\_\_\_\_  
Screen Type & Method of Installation \_\_\_\_\_

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						<input type="checkbox"/>	<input type="checkbox"/>

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:  
20' ft. below ground Artesian pressure \_\_\_\_\_ lb.  
Depth flow encountered \_\_\_\_\_ ft. Describe access port or control devices: \_\_\_\_\_

12. WELL TESTS:  
 Pump  Bailor  Air  Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time

Water Temp. \_\_\_\_\_ Bottom hole temp. \_\_\_\_\_  
Water Quality test or comments: \_\_\_\_\_

13. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8"</u>	<u>0</u>	<u>20'</u>	<u>Clay some Gravel</u>		<input checked="" type="checkbox"/>
<u>6"</u>	<u>20'</u>	<u>60'</u>	<u>Clay Gravel</u>	<input checked="" type="checkbox"/>	

RECEIVED  
JAN 23 2009  
Department of Water Resources  
Eastern Region

Completed Depth 60' (Measurable)  
Date: Started 12-30-08 Completed 12-30-08

14. DRILLER'S CERTIFICATION  
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Dennings Drilling Firm No. 518  
Principal Driller Dennings Date 12-31-08  
and Driller or Operator II Dennings Date 12-31-08  
Operator I \_\_\_\_\_ Date \_\_\_\_\_  
Principal Driller and Rig Operator Required.  
Operator I must have signature of Driller/Operator II.

